

PRACTICE EXAM 14: CTS-I

SIMULATION

QUESTIONS 1–125

Domain A — Conducting Pre-Installation Activities

1. A 1-inch EMT conduit has an internal cross-sectional area of 0.864 square inches. The maximum cable area permitted at 40% fill is:

- A. 0.432 square inches
- B. 0.286 square inches
- C. 0.346 square inches
- D. 0.520 square inches

2. A 2-inch EMT conduit has an internal cross-sectional area of 3.36 square inches. The maximum cable area permitted at 40% fill is:

- A. 1.344 square inches
- B. 1.120 square inches
- C. 1.568 square inches
- D. 1.680 square inches

3. An installer plans 20 cable runs averaging 80 feet. Including 4-foot rack service loops and 4-foot device service loops on each run, the base cable length is:

- A. 1,600 feet
- B. 1,680 feet
- C. 1,720 feet
- D. 1,760 feet

4. Continuing from the previous question, adding 15% contingency to the 1,760-foot base yields total order length of approximately:

- A. 1,936 feet
- B. 2,024 feet
- C. 2,112 feet
- D. 2,200 feet

5. A 0.30-inch diameter cable has cross-sectional area of approximately:

- A. 0.0707 square inches
- B. 0.0472 square inches
- C. 0.0943 square inches
- D. 0.0236 square inches

6. A conduit with 1.496 square inch internal area contains 8 cables at 0.075 square inch each. The fill percentage is:

- A. 35.2%
- B. 38.4%

C. 40.1%

D. 42.3%

7. A wiring schedule lists 180 cable runs requiring labels at both ends. Total labels required:

A. 180 labels

B. 240 labels

C. 300 labels

D. 360 labels

8. A drawing scale of $1/4" = 1'-0"$ shows a wall 8 inches long on the drawing. The actual dimension is:

A. 24 feet

B. 32 feet

C. 16 feet

D. 40 feet

9. A project requires 220 cable ties, 110 velcro straps, and 440 labels. Current inventory shows 80 cable ties, 40 velcro straps, and 200 labels. The procurement gap is:

A. Cable ties: 140, Velcro: 70, Labels: 240

B. Cable ties: 120, Velcro: 60, Labels: 220

C. Cable ties: 140, Velcro: 60, Labels: 220

D. Cable ties: 120, Velcro: 70, Labels: 240

10. A 2.5-inch EMT conduit has internal cross-sectional area of approximately 4.93 square inches. Maximum cable area at 40% fill is:

- A. 1.865 square inches
- B. 1.950 square inches
- C. 1.972 square inches
- D. 2.100 square inches

11. A labor estimate includes 100 baseline hours. Applied productivity factors are 20% increase for occupied building and 10% increase for restricted access. Total estimated hours using multiplicative factors:

- A. 130 hours
- B. 132 hours
- C. 134 hours
- D. 140 hours

12. A display weighs 95 pounds. Required mount/wall capacity at 4:1 safety factor is:

- A. 285 pounds
- B. 320 pounds
- C. 350 pounds
- D. 380 pounds

13. A cable pull passes through 4 bends of 90 degrees each. Cumulative bend angle is:

- A. 180 degrees
- B. 270 degrees

- C. 360 degrees
- D. 450 degrees

14. A conduit fill percentage of 45% for three or more cables indicates:

- A. Exceeds the NEC 40% limit and requires pathway redesign
- B. Meets the NEC 40% limit for three or more cables
- C. Is below the NEC 31% limit for two cables
- D. Complies with the NEC 53% limit for single cables

15. A 0.24-inch diameter cable has cross-sectional area of approximately:

- A. 0.0283 square inches
- B. 0.0378 square inches
- C. 0.0424 square inches
- D. 0.0452 square inches

16. A take-off calculation shows 1,200 feet of cable with 12% contingency. Order length is:

- A. 1,320 feet
- B. 1,344 feet
- C. 1,368 feet
- D. 1,392 feet

17. A drawing scale of $1/8" = 1'-0"$ shows a room 10 inches wide on paper. The actual dimension is:

- A. 80 feet

- B. 64 feet
- C. 56 feet
- D. 72 feet

18. A 12U rack space at 1.75 inches per RU occupies:

- A. 18 inches
- B. 20 inches
- C. 21 inches
- D. 24 inches

19. A 175-pound display mounted at 4:1 safety factor requires mount/wall capacity of:

- A. 600 pounds
- B. 700 pounds
- C. 750 pounds
- D. 800 pounds

20. A project's 3-inch EMT conduit has internal cross-sectional area of approximately 7.38 square inches. Maximum cable area at 40% fill:

- A. 2.625 square inches
- B. 2.700 square inches
- C. 2.850 square inches
- D. 2.952 square inches

21. A cable run of 68 feet with a 5-foot service loop at each end requires base length of:

- A. 78 feet
- B. 80 feet
- C. 82 feet
- D. 85 feet

22. The 80% rule applied to a 15-ampere circuit limits continuous loads to:

- A. 10 amperes
- B. 11 amperes
- C. 12 amperes
- D. 13 amperes

23. A 1.25-inch EMT conduit has internal cross-sectional area of approximately 1.496 square inches. Maximum cable area at 40% fill is:

- A. 0.526 square inches
- B. 0.598 square inches
- C. 0.620 square inches
- D. 0.690 square inches

24. An installer calculates 150 base labor hours. With 25% increase for evening shifts only, total hours are:

- A. 165 hours
- B. 175 hours
- C. 180 hours

D. 187.5 hours

25. A drawing scale of $1/2" = 1'-0"$ shows a distance of 6 inches on paper. The actual dimension is:

A. 8 feet

B. 10 feet

C. 12 feet

D. 14 feet

26. A 16U rack-mount device requires vertical space of:

A. 26 inches

B. 28 inches

C. 30 inches

D. 32 inches

27. A 0.40-inch diameter cable has cross-sectional area of approximately:

A. 0.0754 square inches

B. 0.1005 square inches

C. 0.1178 square inches

D. 0.1257 square inches

28. An OSHA 30-hour construction safety card is primarily required for:

A. Supervisory personnel and competent persons on construction sites

B. General workers on residential projects

- C. Security personnel at construction sites
- D. Delivery drivers accessing construction sites

Domain B — Conducting Site Rough-In/First-Fix

29. A cable pull through conduit with cumulative bend angle of 450 degrees between pull points:

- A. Meets NEC requirements
- B. Is at the NEC limit
- C. Exceeds NEC 360-degree limit and requires intermediate pull point
- D. Is below the NEC 270-degree limit

30. A 3/8-inch A307 threaded rod has tensile failure capacity of approximately 5,700 pounds. Working load at 4:1 non-overhead safety factor is:

- A. 1,140 pounds
- B. 1,425 pounds
- C. 2,280 pounds
- D. 1,900 pounds

31. Continuing from the previous question, the same rod applied to overhead loading at 5:1 safety factor has working load of:

- A. 950 pounds
- B. 1,050 pounds
- C. 1,100 pounds
- D. 1,140 pounds

32. An extension ladder at 4-to-1 rule with base 5 feet from structure has working height of approximately:

- A. 20 feet
- B. 18 feet
- C. 22 feet
- D. 24 feet

33. An OSHA fall protection anchor point requires capacity of 5,000 pounds per worker. For 2 workers simultaneously attached, capacity required is:

- A. 5,000 pounds
- B. 7,500 pounds
- C. 10,000 pounds
- D. 12,500 pounds

34. A cable pull with 3 bends of 90 degrees and 1 bend of 45 degrees has cumulative bend angle of:

- A. 270 degrees
- B. 315 degrees
- C. 360 degrees
- D. 405 degrees

35. A cable with manufacturer-specified minimum bend radius of $4\times$ diameter for a 0.35-inch cable has minimum bend radius of:

- A. 0.35 inches
- B. 0.70 inches
- C. 1.05 inches

D. 1.40 inches

36. A 1/2-inch A307 threaded rod has tensile failure capacity of approximately 10,000 pounds. Working load at 4:1 non-overhead safety factor is:

A. 2,500 pounds

B. 3,000 pounds

C. 3,500 pounds

D. 4,000 pounds

37. A 1/4-inch A307 threaded rod has tensile failure capacity of approximately 2,500 pounds. Working load at 5:1 overhead safety factor is:

A. 400 pounds

B. 450 pounds

C. 500 pounds

D. 550 pounds

38. A cable pull requires 350 pounds of tension against a manufacturer maximum of 500 pounds. The margin to maximum is:

A. 30% margin

B. 35% margin

C. 40% margin

D. 50% margin

39. An extension ladder at 16 feet working height using 4-to-1 rule requires base:

- A. 2 feet from structure
- B. 3 feet from structure
- C. 5 feet from structure
- D. 4 feet from structure

40. A J-hook cable support with 5-foot spacing across a 50-foot cable run requires approximately:

- A. 8 J-hooks
- B. 9 J-hooks
- C. 10 J-hooks
- D. 11 J-hooks

41. A cable with minimum bend radius of $8\times$ diameter installed in position for a 0.25-inch cable requires minimum bend radius of:

- A. 2.0 inches
- B. 2.5 inches
- C. 3.0 inches
- D. 3.5 inches

42. OSHA construction fall protection is required at:

- A. 4 feet or greater
- B. 6 feet or greater
- C. 8 feet or greater

D. 10 feet or greater

Domain C — Installing Audiovisual Systems

43. A 42U rack frame provides vertical mounting height of:

- A. 68 inches
- B. 70 inches
- C. 72 inches
- D. 73.5 inches

44. A 25U rack device occupies:

- A. 40 inches
- B. 42 inches
- C. 43.75 inches
- D. 45 inches

45. The 80% rule applied to a 30-ampere circuit limits continuous loads to:

- A. 24 amperes
- B. 22 amperes
- C. 25 amperes
- D. 27 amperes

46. An amplifier dissipates 200 watts heat. Converting to BTU/hour uses factor 3.412, yielding approximately:

- A. 650 BTU/hour
- B. 682 BTU/hour
- C. 700 BTU/hour
- D. 720 BTU/hour

47. A 500-watt heat load converts to approximately:

- A. 1,500 BTU/hour
- B. 1,600 BTU/hour
- C. 1,700 BTU/hour
- D. 1,706 BTU/hour

48. A 70V amplifier rated at 600 watts should drive total tap loads of approximately:

- A. 600 watts
- B. 500 watts
- C. 480 watts
- D. 450 watts

49. A 70V system has 12 loudspeakers at 10-watt taps and 8 loudspeakers at 20-watt taps. Total tap load is:

- A. 240 watts
- B. 280 watts
- C. 320 watts

D. 360 watts

50. A 70V amplifier rated at 350 watts should drive maximum tap load of approximately:

A. 280 watts

B. 300 watts

C. 320 watts

D. 350 watts

51. Three loudspeakers each at 4 ohms connected in parallel present combined impedance of:

A. 1.33 ohms

B. 4 ohms

C. 8 ohms

D. 12 ohms

52. Four loudspeakers each at 8 ohms connected in parallel present combined impedance of:

A. 4 ohms

B. 3 ohms

C. 2 ohms

D. 8 ohms

53. An 8-ohm loudspeaker with cable resistance limited to 5% of impedance has maximum cable resistance of:

A. 0.20 ohms

- B. 0.40 ohms
- C. 0.60 ohms
- D. 0.80 ohms

54. A 4-ohm loudspeaker with cable resistance limited to 5% of impedance has maximum cable resistance of:

- A. 0.10 ohms
- B. 0.15 ohms
- C. 0.18 ohms
- D. 0.20 ohms

55. A 16-ohm loudspeaker with cable resistance limited to 5% of impedance has maximum cable resistance of:

- A. 0.80 ohms
- B. 0.40 ohms
- C. 0.60 ohms
- D. 1.00 ohm

56. Two 8-ohm loudspeakers in parallel present combined impedance of:

- A. 16 ohms
- B. 8 ohms
- C. 4 ohms
- D. 2 ohms

57. A 3 dB increase in audio power represents a power ratio of:

- A. 4:1
- B. 2:1
- C. 3:1
- D. 10:1

58. A 6 dB increase represents a power ratio of:

- A. 2:1
- B. 3:1
- C. 5:1
- D. 4:1

59. A 10 dB increase represents a power ratio of:

- A. 10:1
- B. 20:1
- C. 5:1
- D. 100:1

60. A 20 dB increase represents a power ratio of:

- A. 10:1
- B. 20:1
- C. 100:1
- D. 200:1

61. A 6 dB voltage increase represents a voltage ratio of:

- A. 1.5:1
- B. 2:1
- C. 3:1
- D. 4:1

62. A 1080p60 video signal at 8-bit color requires approximately:

- A. 3.0 Gbps
- B. 6.0 Gbps
- C. 9.0 Gbps
- D. 4.5 Gbps

63. A 4K60 video signal at 10-bit color with HDR requires approximately:

- A. 24 Gbps
- B. 18 Gbps
- C. 12 Gbps
- D. 36 Gbps

64. A 4K30 video signal at 8-bit color requires approximately:

- A. 12 Gbps
- B. 9 Gbps
- C. 10.2 Gbps
- D. 18 Gbps

65. Cat6A cable supports maximum frequency of:

- A. 250 MHz
- B. 500 MHz
- C. 350 MHz
- D. 1000 MHz

66. Cat6 cable supports maximum frequency of:

- A. 500 MHz
- B. 100 MHz
- C. 350 MHz
- D. 250 MHz

67. OM3 multimode fiber supports 10 Gbps Ethernet to:

- A. 100 meters
- B. 200 meters
- C. 300 meters
- D. 400 meters

68. OM4 multimode fiber supports 10 Gbps Ethernet to:

- A. 400 meters
- B. 300 meters
- C. 200 meters
- D. 100 meters

69. HDBaseT supports 4K60 over Cat6A to maximum distance of:

- A. 50 meters
- B. 75 meters
- C. 200 meters
- D. 100 meters

70. IEEE 802.3at (PoE+) provides power at powered device of:

- A. 12.95 watts
- B. 25.5 watts
- C. 51 watts
- D. 71 watts

71. IEEE 802.3af (basic PoE) provides power at powered device of:

- A. 30 watts
- B. 25.5 watts
- C. 12.95 watts
- D. 51 watts

72. IEEE 802.3bt Type 4 provides power at powered device of:

- A. 71 watts
- B. 51 watts
- C. 25.5 watts
- D. 90 watts

73. A /24 subnet provides usable host addresses of:

- A. 256
- B. 252
- C. 128
- D. 254

74. A /25 subnet provides usable host addresses of:

- A. 128
- B. 126
- C. 254
- D. 250

75. Dante typical latency at standard settings is:

- A. 0.25 to 1 millisecond
- B. 5 to 10 milliseconds
- C. 10 to 20 milliseconds
- D. 50 to 100 milliseconds

76. SDVoE distributes uncompressed 4K60 over network speed of:

- A. 100 Mbps
- B. 1 Gbps
- C. 2.5 Gbps
- D. 10 Gbps

77. A projector with throw ratio 2.2:1 at 22 feet distance produces image width of:

- A. 10 feet
- B. 12 feet
- C. 14 feet
- D. 16 feet

78. A projector with throw ratio 1.8:1 at 27 feet distance produces image width of:

- A. 12 feet
- B. 14 feet
- C. 15 feet
- D. 18 feet

79. A projector with throw ratio 2.0:1 at 30 feet distance produces image width of:

- A. 12 feet
- B. 15 feet
- C. 20 feet
- D. 25 feet

80. AVIXA DISCAS basic decision-making content maximum viewing distance is:

- A. 4 times image height
- B. 6 times image height
- C. 12 times image height
- D. 8 times image height

81. AVIXA DISCAS analytical decision-making content maximum viewing distance is:

- A. 4 times image height
- B. 6 times image height
- C. 8 times image height
- D. 12 times image height

82. The target gamma for standard video content is:

- A. 1.8
- B. 2.0
- C. 2.2
- D. 2.4

83. The target white point for video calibration is:

- A. 5500K
- B. 6500K (D65)
- C. 7500K
- D. 9300K

84. Phantom power for condenser microphones is standardized at:

- A. 12 volts DC
- B. 24 volts DC
- C. 36 volts DC
- D. 48 volts DC

85. The maximum permissible untwist at Cat6A termination is:

- A. 0.5 inches
- B. 0.75 inches
- C. 0.25 inches
- D. 1.0 inches

86. Professional amplifier sizing at 125% of tap load means a 400W amplifier drives maximum tap load of:

- A. 400 watts
- B. 280 watts
- C. 320 watts
- D. 500 watts

87. A 70V system with 20 loudspeakers at 5-watt taps and 10 loudspeakers at 15-watt taps has total tap load of:

- A. 200 watts
- B. 250 watts
- C. 280 watts
- D. 350 watts

88. A 70V amplifier at 1000 watts should drive maximum tap load of approximately:

- A. 900 watts
- B. 850 watts
- C. 700 watts

D. 800 watts

Domain D — Perform Systems Close-Out

89. ANSI/AVIXA 10:2013 categorizes verification items into:

- A. A-Level, B-Level, C-Level
- B. Level 1, Level 2, Level 3
- C. Primary, Secondary, Tertiary
- D. Critical, Important, Optional

90. A punch list with 20 items classifies 8 as substantive and 12 as cosmetic. The substantive percentage is:

- A. 30%
- B. 35%
- C. 40%
- D. 45%

91. A 12-month warranty beginning at substantial completion on January 15 expires on:

- A. January 14 following year
- B. January 15 following year
- C. February 15 following year
- D. December 15 same year

92. A typical AV installation with 7-year service life reaching year 5 has remaining service life of approximately:

- A. 4 years
- B. 3 years
- C. 2.5 years
- D. 2 years

93. A preventive maintenance schedule with annual visits over 10 years of service life includes:

- A. 10 visits
- B. 9 visits
- C. 12 visits
- D. 15 visits

94. A service agreement with 4-hour response time means service personnel arrive on site within:

- A. 4 hours of notification
- B. 4 business hours of notification
- C. 4 hours of arrival confirmation
- D. 4 days of notification

95. An installation with 50 cables requires verification testing of each cable. At 3 minutes per cable test, total time is:

- A. 125 minutes
- B. 150 minutes
- C. 175 minutes

D. 200 minutes

96. A rack with 35U of equipment plus 5U of blanking panels plus 2U of reserved space uses rack space of:

A. 35 RU

B. 40 RU

C. 37 RU

D. 42 RU

97. A substantial completion milestone at 85% project completion leaves remaining work of:

A. 15%

B. 10%

C. 20%

D. 25%

98. A client training session for 8 users at 45 minutes each in parallel groups of 4 takes:

A. 180 minutes

B. 135 minutes

C. 90 minutes

D. 45 minutes

99. A warranty period of 12 months plus manufacturer extended warranty of 24 months provides total coverage of:

A. 24 months

- B. 36 months
- C. 48 months
- D. 60 months

100. A project with 500 cables tested for certification at 4 minutes per cable requires total time of:

- A. 1,500 minutes
- B. 1,800 minutes
- C. 1,900 minutes
- D. 2,000 minutes

101. A systematic verification process covers A-Level essential items first. The A-Level proportion of typical verification effort is approximately:

- A. 60-70% of verification effort
- B. 40-50%
- C. 30-40%
- D. 20-30%

102. A substantial completion certificate documents:

- A. System ready for intended use with minor work remaining
- B. All work complete including punch list
- C. Installation cost summary
- D. Warranty terms summary

Domain E — Conducting Ongoing Project Responsibilities

103. A 10-year-old installation experiencing increasing service calls, decreased reliability, and parts unavailability is approximately:

- A. At beginning of service life
- B. At end of service life approaching refresh
- C. Due for manufacturer warranty claims
- D. Due for preventive maintenance

104. A service agreement with quarterly visits over a year provides:

- A. 2 visits per year
- B. 3 visits per year
- C. 4 visits per year
- D. 6 visits per year

105. An annual preventive maintenance schedule for a 7-year service life installation includes total visits of:

- A. 7 visits
- B. 8 visits
- C. 6 visits
- D. 10 visits

106. A labor estimate of 80 hours with 20% productivity increase for evening shifts requires:

- A. 90 hours

- B. 95 hours
- C. 100 hours
- D. 96 hours

107. A 150-hour labor estimate with 15% increase for occupied building plus 10% increase for trade coordination requires approximately:

- A. 175 hours
- B. 189 hours
- C. 195 hours
- D. 200 hours

108. A project with 40% labor and 60% material cost of \$100,000 total has labor cost of:

- A. \$30,000
- B. \$35,000
- C. \$40,000
- D. \$50,000

109. A change order for \$5,000 on a \$100,000 project represents percentage of:

- A. 5%
- B. 10%
- C. 15%
- D. 20%

110. A 30-day delay on a 180-day project represents percentage of:

- A. 10%
- B. 15%
- C. 12.5%
- D. 16.67%

111. A weekly preventive maintenance over a year includes:

- A. 12 visits
- B. 50 visits
- C. 52 visits
- D. 365 visits

112. A biannual preventive maintenance (2 times per year) over 5 years includes:

- A. 8 visits
- B. 10 visits
- C. 12 visits
- D. 5 visits

113. A 25% overrun on a 200-hour labor estimate actual hours total:

- A. 250 hours
- B. 240 hours
- C. 275 hours
- D. 300 hours

114. A project budget of \$80,000 with 10% contingency has total budget of:

- A. \$85,000
- B. \$87,000
- C. \$88,000
- D. \$90,000

115. A service response time requirement of 4 business hours for a call received at 3 PM Friday (Friday close at 5 PM, Monday open at 9 AM) has service arrival by:

- A. 5 PM Friday
- B. 9 AM Monday
- C. 11 AM Monday
- D. 1 PM Monday

116. A typical AV installation service life of 7-10 years has average service life of approximately:

- A. 7 years
- B. 8.5 years
- C. 9 years
- D. 10 years

117. An installation with annual preventive maintenance visits plus 2 additional call-out services per year over 8 years has total service interactions of:

- A. 24 service interactions
- B. 32 service interactions
- C. 40 service interactions

D. 16 service interactions

118. A project with 125 simulation exam questions reviewed at 1 minute per question total:

A. 100 minutes

B. 115 minutes

C. 125 minutes

D. 150 minutes

119. A scope change request submitted Monday receives client approval Wednesday. Resolution time is:

A. 1 day

B. 2 days

C. 3 days

D. 4 days

120. A 20% increase in labor hours on a 100-hour estimate results in actual hours of:

A. 100 hours

B. 110 hours

C. 115 hours

D. 120 hours

121. A service level agreement (SLA) with 99.9% uptime represents maximum allowed downtime per year of:

A. 8.76 hours

- B. 12 hours
- C. 24 hours
- D. 48 hours

122. A 60-hour labor estimate with 50% productivity reduction due to difficult site conditions requires:

- A. 75 hours
- B. 80 hours
- C. 90 hours
- D. 100 hours

123. A project with 10 cables pulled at 5 feet per minute covers 300 feet in:

- A. 50 minutes
- B. 60 minutes
- C. 75 minutes
- D. 90 minutes

124. A preventive maintenance visit with 2-hour duration completed for 12 different clients consumes:

- A. 18 hours
- B. 20 hours
- C. 22 hours
- D. 24 hours

125. A 3-hour training session attended by 20 users represents training hours of:

- A. 60 user-hours
- B. 45 user-hours
- C. 30 user-hours
- D. 20 user-hours

PRACTICE EXAM 14: ANSWER KEY

WITH FULL ANSWER EXPLANATIONS

Questions 1–125

Domain A — Conducting Pre-Installation Activities

1. C — 0.346 square inches. The 40% fill limit multiplied by 0.864 square inches internal area equals 0.346 square inches. This calculation determines the maximum cable cross-sectional area allowed per NEC for three or more cables in the conduit.
2. A — 1.344 square inches. The 40% fill multiplied by 3.36 square inches equals 1.344 square inches. This is the NEC-compliant maximum cable area for three or more cables in a 2-inch EMT conduit.
3. D — 1,760 feet. Each run is $80 + 4 + 4 = 88$ feet including service loops; $20 \text{ runs} \times 88 \text{ feet} = 1,760$ feet total base length. This calculation captures both the physical pathway and service loops before contingency.
4. B — 2,024 feet. $1,760 \text{ feet} \times 1.15$ (15% contingency) equals 2,024 feet. Contingency accounts for routing variations, waste at terminations, and unforeseen field conditions.
5. A — 0.0707 square inches. Cross-sectional area = $\pi \times (d/2)^2 = \pi \times (0.15)^2 = \pi \times 0.0225 \approx 0.0707$ square inches. This formula applies to all circular cable cross-sections.
6. C — 40.1%. Total cable area is $8 \times 0.075 = 0.600$ square inches; dividing by 1.496 square inches equals approximately 40.1%. This slightly exceeds the NEC 40% limit, requiring pathway reassessment.
7. D — 360 labels. $180 \text{ cables} \times 2 \text{ ends per cable} = 360$ labels. Bilateral labeling supports tracing from either end of each cable.
8. B — 32 feet. At $1/4" = 1'-0"$ scale, $8 \text{ inches} \times 4 \text{ feet per inch} = 32$ feet. Scale conversion converts drawing dimensions to actual building dimensions.
9. A — Cable ties: 140, Velcro: 70, Labels: 240. Cable ties: $220 - 80 = 140$ gap. Velcro: $110 - 40 = 70$ gap. Labels: $440 - 200 = 240$ gap. Accurate gap calculation supports complete procurement.

10. C — 1.972 square inches. $4.93 \times 0.40 = 1.972$ square inches. This is the maximum cable area allowed in 2.5-inch EMT at NEC's 40% fill limit.
11. B — 132 hours. 100×1.20 (occupied) = 120 hours, then $\times 1.10$ (restricted access) = 132 hours. Multiplicative productivity factors compound when conditions combine.
12. D — 380 pounds. $95 \times 4 = 380$ pounds minimum capacity. The 4:1 safety factor for non-overhead loads accounts for dynamic loading, fatigue, and installation imperfections.
13. C — 360 degrees. 4 bends $\times 90$ degrees = 360 degrees cumulative. This is exactly at the NEC limit between pull points; additional bends require intermediate pull boxes.
14. A — Exceeds the NEC 40% limit and requires pathway redesign. 45% fill exceeds NEC's 40% limit for three or more cables, creating a code violation requiring resolution through pathway upsizing or cable reduction.
15. D — 0.0452 square inches. $\pi \times (0.12)^2 = \pi \times 0.0144 \approx 0.0452$ square inches. This calculation applies consistently to cable cross-sectional area analysis.
16. B — 1,344 feet. $1,200 \times 1.12$ (12% contingency) = 1,344 feet. Contingency percentages vary by project risk but typically range 10-15%.
17. A — 80 feet. At $1/8" = 1'-0"$ scale, 10 inches $\times 8$ feet per inch = 80 feet. Smaller scales allow larger areas to fit on drawing sheets.
18. C — 21 inches. 12 RU $\times 1.75$ inches per RU = 21 inches. Multiplying rack units by 1.75 gives precise vertical space.
19. B — 700 pounds. $175 \times 4 = 700$ pounds at the 4:1 non-overhead safety factor. Higher-weight equipment requires proportionally higher mount/wall capacity.
20. D — 2.952 square inches. $7.38 \times 0.40 = 2.952$ square inches. Three-inch EMT provides substantial cable capacity.
21. A — 78 feet. $68 + 5 + 5 = 78$ feet base length including both service loops. This calculation precedes contingency application.
22. C — 12 amperes. $15 \times 0.80 = 12$ amperes. The 80% rule limits continuous loads to 80% of circuit rating to provide headroom against breaker trips.
23. B — 0.598 square inches. $1.496 \times 0.40 = 0.598$ square inches. This is the maximum cable area allowed in 1.25-inch EMT at NEC's 40% fill limit.
24. D — 187.5 hours. $150 \times 1.25 = 187.5$ hours. Single-factor productivity calculations apply the factor directly to base hours.
25. C — 12 feet. At $1/2" = 1'-0"$ scale, 6 inches $\times 2$ feet per inch = 12 feet. Larger scales show greater detail but cover smaller areas.

26. B — 28 inches. $16 \text{ RU} \times 1.75 = 28$ inches vertical mounting space. This is precisely calculated for all rack unit sizes.
27. D — 0.1257 square inches. $\pi \times (0.20)^2 = \pi \times 0.04 \approx 0.1257$ square inches. Larger diameter cables have substantially greater cross-sectional area.
28. A — Supervisory personnel and competent persons on construction sites. The OSHA 30-hour card provides expanded safety training required for supervisors and competent persons, distinguishing it from the 10-hour card for general workers.

Domain B — Conducting Site Rough-In/First-Fix

29. C — Exceeds NEC 360-degree limit and requires intermediate pull point. 450 degrees exceeds NEC Chapter 9's 360-degree cumulative bend limit between pull points. This requires adding an intermediate pull box to reduce cumulative bends.
30. B — 1,425 pounds. $5,700 \div 4 = 1,425$ pounds working load. The 4:1 non-overhead safety factor provides margin for dynamic loads, fatigue, and installation imperfections.
31. D — 1,140 pounds. $5,700 \div 5 = 1,140$ pounds working load. Overhead loads require the higher 5:1 safety factor because of the greater consequences of failure above occupied spaces.
32. A — 20 feet. At the 4-to-1 rule, base 5 feet from structure supports $5 \times 4 = 20$ feet working height. This ratio produces approximately 75-degree ladder angle for safe use.
33. C — 10,000 pounds. $5,000 \text{ pounds} \times 2 \text{ workers} = 10,000$ pounds minimum anchor capacity. Multiple workers attached multiply the anchor requirement proportionally.
34. B — 315 degrees. $3 \times 90 + 1 \times 45 = 270 + 45 = 315$ degrees cumulative. This is below NEC's 360-degree limit, allowing continued pulling.
35. D — 1.40 inches. $4 \times 0.35 = 1.40$ inches minimum bend radius during installation. Respecting this limit prevents internal cable geometry damage.
36. A — 2,500 pounds. $10,000 \div 4 = 2,500$ pounds working load at 4:1 safety factor. This is the non-overhead working capacity of the 1/2-inch rod.
37. C — 500 pounds. $2,500 \div 5 = 500$ pounds working load at 5:1 overhead safety factor. The higher safety factor for overhead loads produces lower working capacity.
38. A — 30% margin. $(500 - 350) \div 500 = 0.30$ or 30% margin below maximum. This margin provides safety against exceeding manufacturer limits during variable pulling conditions.
39. D — 4 feet from structure. $16 \div 4 = 4$ feet. The 4-to-1 rule means the base extends 1 foot per 4 feet of working height, producing stable climbing angle.
40. C — 10 J-hooks. $50 \text{ feet} \div 5 \text{ feet per J-hook} = 10$ J-hooks needed for the run. This standard spacing supports typical Category cable without excessive sag.

41. A — 2.0 inches. $8 \times 0.25 = 2.0$ inches minimum bend radius in installed position. Installed position uses the looser $8\times$ diameter limit versus $4\times$ during pulling.
42. B — 6 feet or greater. OSHA construction fall protection (29 CFR 1926 Subpart M) requires fall protection at 6 feet or greater. This is the standard construction site trigger.

Domain C — Installing Audiovisual Systems

43. D — 73.5 inches. $42 \text{ RU} \times 1.75 = 73.5$ inches. Full-size racks provide substantial vertical equipment capacity.
44. C — 43.75 inches. $25 \text{ RU} \times 1.75 = 43.75$ inches. Accurate calculation requires the exact 1.75 multiplier.
45. A — 24 amperes. $30 \times 0.80 = 24$ amperes continuous load limit. This protects against sustained near-rated current draw causing breaker trips.
46. B — 682 BTU/hour. $200 \times 3.412 = 682$ BTU/hour. The factor 3.412 converts watts to BTU/hour for HVAC calculations.
47. D — 1,706 BTU/hour. $500 \times 3.412 = 1,706$ BTU/hour. Larger heat loads require proportionally more cooling capacity.
48. C — 480 watts. $600 \div 1.25 = 480$ watts. Professional practice sizes amplifiers at 125% of tap load, providing 80% utilization and operating headroom.
49. B — 280 watts. $12 \times 10 + 8 \times 20 = 120 + 160 = 280$ watts total tap load. Summing all loudspeaker taps gives the amplifier demand.
50. A — 280 watts. $350 \div 1.25 = 280$ watts maximum tap load. This preserves the 80% utilization standard.
51. A — 1.33 ohms. $4 \div 3 \approx 1.33$ ohms. Three equal parallel impedances equal one impedance divided by three.
52. C — 2 ohms. $8 \div 4 = 2$ ohms. Four equal 8-ohm loudspeakers in parallel halve the impedance twice.
53. B — 0.40 ohms. 5% of 8 ohms = 0.40 ohms maximum cable resistance. This limit preserves power transfer efficiency and prevents protection circuit triggering.
54. D — 0.20 ohms. 5% of 4 ohms = 0.20 ohms. Lower impedance loudspeakers have proportionally lower cable resistance tolerance.
55. A — 0.80 ohms. 5% of 16 ohms = 0.80 ohms. Higher impedance loudspeakers tolerate higher cable resistance.

56. C — 4 ohms. Two 8-ohm loudspeakers in parallel: $8 \div 2 = 4$ ohms. Two equal parallel impedances halve the single impedance.
57. B — 2:1. A 3 dB power increase represents $2\times$ power ratio. This is one of the key decibel reference values.
58. D — 4:1. A 6 dB power increase represents $4\times$ power ratio. Also corresponds to $2\times$ voltage ratio since power scales with voltage squared.
59. A — 10:1. A 10 dB power increase represents $10\times$ power ratio. The dB scale is logarithmic with 10 dB representing one decade of power.
60. C — 100:1. A 20 dB increase represents $100\times$ power ratio. Each 10 dB increment multiplies the ratio by 10.
61. B — 2:1. A 6 dB voltage increase represents $2\times$ voltage ratio. Voltage uses the $20 \times \log$ multiplier rather than $10 \times \log$ used for power.
62. D — 4.5 Gbps. 1080p60 at 8-bit color requires approximately 4.5 Gbps bandwidth. This is a fundamental bandwidth specification for HD video.
63. A — 24 Gbps. 4K60 at 10-bit color with HDR requires approximately 24 Gbps, exceeding HDMI 2.0's 18 Gbps capacity.
64. C — 10.2 Gbps. 4K30 at 8-bit color requires approximately 10.2 Gbps bandwidth. Lower frame rate reduces bandwidth compared to 4K60.
65. B — 500 MHz. Cat6A supports 500 MHz maximum frequency, twice Cat6's 250 MHz and supporting 10GBase-T.
66. D — 250 MHz. Cat6 supports 250 MHz maximum frequency, midway between Cat5e (100 MHz) and Cat6A (500 MHz).
67. C — 300 meters. OM3 multimode fiber supports 10 Gbps Ethernet to 300 meters, substantially exceeding copper limits.
68. A — 400 meters. OM4 multimode fiber supports 10 Gbps Ethernet to 400 meters, improving on OM3's 300-meter capability.
69. D — 100 meters. HDBaseT supports 4K60 over Cat6A to 100 meters, matching general Ethernet limits.
70. B — 25.5 watts. IEEE 802.3at (PoE+) provides 25.5 watts at the powered device, with 30 watts at the source.
71. C — 12.95 watts. IEEE 802.3af (basic PoE) provides 12.95 watts at the powered device, with 15.4 watts at the source.

72. A — 71 watts. IEEE 802.3bt Type 4 provides 71 watts at the powered device, with 100 watts at the source.
73. D — 254. A /24 subnet provides 256 total addresses minus 2 reserved (network and broadcast) = 254 usable host addresses.
74. B — 126. A /25 subnet provides 128 total addresses minus 2 reserved = 126 usable host addresses.
75. A — 0.25 to 1 millisecond. Dante audio networking operates with extremely low latency at standard settings, essential for professional audio.
76. D — 10 Gbps. SDVoE distributes uncompressed 4K60 video requiring 10 Gbps Ethernet infrastructure plus protocol overhead.
77. A — 10 feet. Image width = distance ÷ throw ratio = 22 ÷ 2.2 = 10 feet. This formula determines image size from projector positioning.
78. C — 15 feet. Image width = 27 ÷ 1.8 = 15 feet. The same formula applies to all throw ratio calculations.
79. B — 15 feet. Image width = 30 ÷ 2.0 = 15 feet. Throw ratio calculations are fundamental to projector positioning planning.
80. D — 8 times image height. AVIXA DISCAS recommends 8× image height maximum viewing distance for basic decision-making content (text readable from back).
81. A — 4 times image height. Analytical decision-making content requires shorter 4× image height maximum viewing distance, half the basic distance for finer detail discrimination.
82. C — 2.2. Standard video content is encoded for gamma 2.2, matching human visual perception and content encoding standards.
83. B — 6500K (D65). D65 white point at 6500 Kelvin is the standard for video content calibration.
84. D — 48 volts DC. Phantom power for condenser microphones is standardized at 48V DC.
85. A — 0.5 inches. Cat6A cable specifications permit maximum 0.5 inches of untwist at termination to preserve high-frequency performance.
86. C — 320 watts. $400 \div 1.25 = 320$ watts. Professional 125% sizing provides operating headroom for amplifiers.
87. B — 250 watts. $20 \times 5 + 10 \times 15 = 100 + 150 = 250$ watts total tap load.
88. D — 800 watts. $1000 \div 1.25 = 800$ watts maximum tap load. The 125% sizing rule applies at all amplifier capacities.

Domain D — Perform Systems Close-Out

89. A — A-Level, B-Level, C-Level. ANSI/AVIXA 10:2013 uses this three-level structure categorizing verification items as essential, specialized, and unique.
90. C — 40%. $8 \text{ substantive} \div 20 \text{ total} = 40\%$. Percentage calculations support punch list priority assessment.
91. B — January 15 following year. A 12-month warranty period from January 15 expires exactly 12 months later on January 15 of the following year.
92. D — 2 years. $7 \text{ years service life} - 5 \text{ years elapsed} = 2 \text{ years remaining}$. Service life tracking supports refresh planning.
93. A — 10 visits. $\text{Annual visits} \times 10 \text{ years} = 10 \text{ visits total}$. Preventive maintenance planning multiplies visit frequency by service life.
94. C — 4 hours of arrival confirmation. Service level agreements typically define response time as time to arrival, with specific definitions varying by contract terms.
95. B — 150 minutes. $50 \text{ cables} \times 3 \text{ minutes} = 150 \text{ minutes total test time}$. Planning calculations support schedule development.
96. D — 42 RU. $35 + 5 + 2 = 42 \text{ RU total rack space used including equipment, blanking panels, and reserved space}$.
97. A — 15%. $100\% - 85\% = 15\% \text{ remaining work}$. Percentage calculations support progress tracking and completion planning.
98. C — 90 minutes. Two parallel sessions of 45 minutes each = 90 minutes total. Parallel execution reduces total elapsed time.
99. B — 36 months. $12 \text{ months} + 24 \text{ months} = 36 \text{ months total warranty coverage}$. Warranty extensions add to base coverage periods.
100. D — 2,000 minutes. $500 \times 4 = 2,000 \text{ minutes total test time}$. Large cable counts require significant testing effort.
101. A — 60-70% of verification effort. A-Level items typically represent the majority of verification effort because they cover essential system functions that must be verified on every installation.
102. D — Warranty terms summary. The certificate documents system readiness at milestone achievement with remaining punch list items scheduled for completion.

Domain E — Conducting Ongoing Project Responsibilities

103. B — At end of service life approaching refresh. Increasing service calls, decreasing reliability, and parts unavailability are classic end-of-life indicators signaling approaching refresh.

104. C — 4 visits per year. Quarterly visits \times 4 quarters = 4 visits per year. Maintenance scheduling directly corresponds to agreed frequency.
105. A — 7 visits. Annual visits \times 7 years = 7 visits total during service life.
106. D — 96 hours. $80 \times 1.20 = 96$ hours with 20% productivity increase. Evening shift productivity reductions are applied multiplicatively.
107. B — 189 hours. $150 \times 1.15 \times 1.10 = 189.75$, approximately 189 hours. Compound productivity factors apply multiplicatively.
108. C — \$40,000. $40\% \times \$100,000 = \$40,000$ labor cost. This is standard percentage-of-total calculation.
109. A — 5%. $\$5,000 \div \$100,000 = 5\%$. Change order percentages measure contract impact.
110. D — 16.67%. $30 \div 180 = 16.67\%$. Delay percentages measure impact relative to original schedule.
111. C — 52 visits. Weekly visits \times 52 weeks = 52 visits per year. Weekly maintenance is substantial investment.
112. B — 10 visits. 2 visits per year \times 5 years = 10 visits total. Biannual scheduling doubles annual frequency.
113. A — 250 hours. $200 \times 1.25 = 250$ hours with 25% overrun. Overruns add to baseline hours.
114. C — \$88,000. $\$80,000 \times 1.10 = \$88,000$ with 10% contingency. Contingency adds percentage margin to baseline.
115. D — 1 PM Monday. Business hours only: Friday 3-5 PM = 2 hours, Monday 9-11 AM needs 2 more hours, totaling 4 hours. Service arrives by 1 PM Monday considering business hours definition.
116. B — 8.5 years. $(7 + 10) \div 2 = 8.5$ years average. Range-based averages use midpoint calculation.
117. A — 24 service interactions. 1 annual + 2 additional = 3 per year \times 8 years = 24 total. Comprehensive service tracking combines scheduled and unscheduled visits.
118. C — 125 minutes. 125 questions \times 1 minute = 125 minutes. Straightforward multiplication for planning purposes.
119. B — 2 days. Monday to Wednesday = 2 days elapsed. Resolution tracking measures elapsed time.
120. D — 120 hours. $100 \times 1.20 = 120$ hours with 20% increase. Direct percentage applications scale baseline values.
121. A — 8.76 hours. 365 days \times 24 hours \times 0.1% = 8.76 hours. 99.9% uptime allows 0.1% downtime per year.

122. C — 90 hours. $60 \times 1.50 = 90$ hours. A 50% productivity reduction effectively increases hours by 50%.
123. B — 60 minutes. $300 \text{ feet} \div 5 \text{ feet per minute} = 60$ minutes. Linear rate calculations determine time requirements.
124. D — 24 hours. $12 \text{ clients} \times 2 \text{ hours} = 24$ hours total. Multiple-client scheduling totals individual visit durations.
125. A — 60 user-hours. $20 \text{ users} \times 3 \text{ hours} = 60$ user-hours. User-hours measure total training investment across participants.