

PRACTICE EXAM 16: PE POWER SIMULATION (80 QUESTIONS)

1. A 13.8 kV industrial facility has a three-phase fault level of 520 MVA and an SLG fault level of 600 MVA at the main bus. The facility proposes replacing six aging six-pulse VFDs totaling 4,000 HP with new 18-pulse VFDs and simultaneously installing a 7,200 kvar capacitor bank. The resonant harmonic order is $h_r = \sqrt{(520,000/7,200)} = 8.50$. After the retrofit, what changes in the harmonic resonance risk assessment?

- A. The risk increases because the 18-pulse VFDs shift harmonic energy to higher-order frequencies closer to $h_r = 8.50$
- B. The risk decreases significantly — 18-pulse VFDs eliminate the 5th and 7th harmonics that are nearest to $h_r = 8.50$; the lowest remaining characteristic harmonic (11th) is well above the resonant frequency, reducing the likelihood of resonance excitation
- C. The risk is unchanged because the resonant frequency depends only on system fault level and capacitor size, not VFD pulse count
- D. The risk increases because 18-pulse VFDs produce higher-magnitude 11th-harmonic current that could excite the 8.50 resonant frequency

2. A three-phase, 480V, solidly grounded wye system has a 3,000 kVA service transformer ($Z = 5.75\%$, $X/R = 9$) feeding a switchboard. The switchboard serves a critical data center MCC through a 550-foot cable run of 500 kcmil copper in steel conduit ($R = 0.0276 \Omega/1000 \text{ ft}$, $X = 0.0391 \Omega/1000 \text{ ft per phase}$). The engineer must compare the arc flash incident energy at the switchboard versus the remote MCC to determine whether separate PPE categories are required. If the switchboard has 36,130A available and 12 cal/cm² at 0.1-second clearing, what is the approximate available fault current at the MCC?

- A. 36,130A (cable is negligible at 550 feet for 500 kcmil)
- B. 28,500A
- C. 22,000A
- D. 18,800A

3. Per NEC 430.52(C)(1), a 450 HP, 460V, three-phase Design B motor has a Table 430.250 FLA of 515A. The maximum inverse-time breaker at 250% is 1,287.5A → next standard 1,400A. However, the motor fails to start with this breaker. Exception 1 permits 400% = 2,060A. The next standard size not exceeding 2,060A is 2,000A. An engineer instead selects a 2,500A breaker. Is this compliant?

- A. Yes — the next standard above 2,060A provides additional margin for high-inertia loads
- B. No — NEC 430.52(C)(1) Exception 1 permits 400% of FLA for inverse-time breakers, and the OCPD must not exceed this value
- C. No — 2,500A exceeds the 400% limit of 2,060A; the maximum standard size not exceeding 2,060A is 2,000A, and no further increase is permitted under Exception 1
- D. Yes — Exception 2 automatically applies when Exception 1 is insufficient

4. A CT with a ratio of 4000:5 and accuracy class C800 serves a generator differential relay. During an internal fault of 48,000A, the CT secondary current is 60A (12× rated). The total burden is 6.0 Ω. The voltage across the burden is 360V. At 20× rated (100A), the C800 guarantee applies. At the actual 12× operating point, is the CT performing within its capability?

- A. Yes — at 12× rated, the CT core requires less excitation than at 20× rated; 360V is well within the CT's voltage capability at this operating point because the C800 rating guarantees 800V at a higher current multiple
- B. No — 360V exceeds the proportional rating at 12× ($800V \times 12/20 = 480V$ is the limit)
- C. Yes — but only because the C800 rating includes a built-in 2× safety factor
- D. No — the burden of 6.0 Ω exceeds the maximum recommended for C800 CTs

5. A 345 kV, 350-mile transmission line has $Z = 0.06 + j0.70 \Omega/\text{mile}$ and $Y = j5.0 \times 10^{-6} \text{ S/mile}$ per phase. The line is energized from the sending end at rated voltage with the receiving end open. At 350 miles, the Ferranti effect voltage rise is severe. The engineer considers installing a 150 Mvar shunt reactor at the open receiving end. What does the reactor accomplish, and what happens if the reactor trips offline while the line is open?

- A. The reactor reduces the Ferranti effect to approximately 5%; if it trips, the voltage rise returns to its uncompensated level
- B. The reactor has no effect on the Ferranti voltage rise because it is connected at the receiving end

C. The reactor absorbs excess capacitive charging current; if it trips, the sending-end generator may be overloaded with reactive power

D. The reactor absorbs the excess reactive power generated by the line's shunt capacitance, limiting the receiving-end voltage rise to a safe level; if the reactor trips while the line is open, the voltage at the open end rises sharply, potentially exceeding equipment insulation ratings and causing flashovers or arrester failures

6. Per NEC 250.122(B), a 250A circuit has phase conductors increased from 4/0 AWG (211,600 CM) to 350 kcmil (350,000 CM) for voltage drop on a long run. The minimum EGC from Table 250.122 for a 250A OCPD is 4 AWG (41,740 CM). What is the proportionally increased EGC size?

A. 4 AWG (no increase needed for circuits under 400A)

B. 2 AWG (66,360 CM) — ratio = $350,000/211,600 = 1.654$; $EGC = 41,740 \times 1.654 = 69,037$ CM → next standard above is 2 AWG (66,360 CM)... actually 2 AWG is 66,360 which is below 69,037; the next size is 1 AWG (83,690 CM)

C. 3 AWG (52,620 CM) — insufficient based on proportional calculation

D. 6 AWG (standard EGC for all 250A circuits)

7. A three-phase, 4,160V, 60 Hz system has a 5,000 kW load at 0.74 lagging PF. The feeder impedance is $Z = 0.45 + j2.60 \Omega$ per phase. The engineer compares two power factor correction approaches: Approach 1 installs a 4,000 kvar capacitor bank; Approach 2 installs a 2,500 HP synchronous motor at 0.80 leading PF ($\eta = 95\%$) plus a 1,500 kvar capacitor bank. Which approach provides the best combined benefit of power factor correction AND additional production capacity?

A. Approach 2 — the synchronous motor provides approximately 1,485 kvar reactive plus 2,500 HP shaft output, and the 1,500 kvar capacitor adds to the total correction, producing approximately 2,985 kvar total reactive support while adding mechanical capacity; Approach 1's 4,000 kvar provides more reactive correction but no shaft output

B. Approach 1 — the capacitor bank always provides superior power factor correction

C. Both approaches are equivalent because they provide the same total kvar

D. Approach 2 — but only if the synchronous motor replaces an existing induction motor load

8. A three-phase, 480Y/277V panelboard serves an office building with 45% linear fluorescent lighting, 45% nonlinear LED drivers (producing significant 3rd harmonic), and 10% small motor loads. Each

phase draws 300A fundamental current and 90A of third-harmonic current. The neutral current is $3 \times 90 = 270\text{A}$. The conduit contains 3 phase + 1 neutral conductor. Per NEC 310.15(C)(1), the neutral is counted as current-carrying (4 conductors, factor = 0.80). What is the minimum required conductor ampacity before applying the 0.80 adjustment factor?

- A. 300A (phase current governs — phase conductors need $300/0.80 = 375\text{A}$ base ampacity)
- B. 375A (phase conductor base ampacity)
- C. The conductor selection must satisfy BOTH phase and neutral requirements: phase needs $300/0.80 = 375\text{A}$; neutral needs $270/0.80 = 337.5\text{A}$; the phase governs at 375A for a unified conductor selection
- D. 337.5A (neutral current governs because it is the highest harmonic-carrying conductor)

9. A 125 MVA synchronous generator has $X''_d = 0.18$ pu, $X_2 = 0.20$ pu, $X_0 = 0.07$ pu on its own base. The generator is grounded through a 1.5Ω resistor. $Z_{\text{base}} = (18)^2/125 = 2.592 \Omega$. $R_n(\text{pu}) = 1.5/2.592 = 0.579$ pu. In the zero-sequence network, $3R_n = 1.736$ pu. For a bolted SLG fault at the terminals, what is the subtransient SLG fault current, and what is the character (angle) of the fault current?

- A. $I_{\text{SLG}} = 6.0$ pu; predominantly reactive (similar to solidly grounded)
- B. $I_{\text{SLG}} = 3.0$ pu; predominantly resistive due to the grounding resistor
- C. $I_{\text{SLG}} = 1.5$ pu; purely resistive at exactly the NGR current rating
- D. $I_{\text{SLG}} \approx 1.55$ pu; predominantly resistive because $3R_n$ (1.736 pu) dominates the zero-sequence impedance, making the total fault impedance mostly real; the fault current lags the voltage by approximately 15° rather than the $80\text{-}85^\circ$ typical of solidly grounded systems

10. A three-phase, 4,160V system has a neutral grounding resistor rated 250A, 10 seconds. The system has 15A of distributed zero-sequence capacitive charging current. During a ground fault through a 12Ω fault resistance, the NGR resistance is $R_{\text{NGR}} = 2,402/250 = 9.608 \Omega$. What is the fault current, and what percentage of the NGR's I^2t thermal capacity is consumed if the relay clears in 2.0 seconds?

- A. $I = 250\text{A}$; 10% consumed
- B. $I = 111\text{A}$; I^2t consumed = $111^2 \times 2.0 = 24,642 \text{ A}^2\text{s}$; rated = $250^2 \times 10 = 625,000 \text{ A}^2\text{s}$; consumed = 3.9%
- C. $I = 200\text{A}$; 16% consumed
- D. $I = 55\text{A}$; 1% consumed

11. Per NEC 110.34(A), the minimum working space depth for equipment rated 9,001V to 25,000V under Condition 1 (exposed live parts on one side, no grounded parts on the other) is what distance?

- A. 5 feet
- B. 6 feet
- C. 4 feet
- D. 8 feet

12. A 2,000 kVA, 13.8 kV/480V transformer has core losses of 5,500 W and full-load copper losses of 18,000 W. The transformer serves a manufacturing facility with a variable load profile: 8 hours at 90% load (PF = 0.92), 8 hours at 60% load (PF = 0.85), and 8 hours at 25% load (PF = 0.70). At what loading does maximum efficiency occur, and what is the all-day efficiency?

- A. k_{max} at 90%; $\eta_{\text{allday}} = 96.0\%$
- B. k_{max} at 60%; $\eta_{\text{allday}} = 97.0\%$
- C. $k_{\text{max}} = \sqrt{(5,500/18,000)} = 55.3\%$; the 60% loading period is closest; $\eta_{\text{allday}} \approx 97.4\%$
- D. k_{max} at 100%; $\eta_{\text{allday}} = 95.5\%$

13. A protection coordination study for a 4,160V industrial system requires coordinating a 300A expulsion fuse on a motor feeder with an upstream 51 relay (IEEE very inverse, TD = 3.5, pickup = 6A on 800:5 CT). At a maximum fault current of 12,000A, the fuse total clearing time is 0.006 seconds. The relay secondary current = $12,000/(800/5) = 75\text{A}$. $M = 75/6 = 12.5$. Using the IEEE very inverse formula $t = \text{TD} \times (19.61/(M^2 - 1) + 0.491)$, what is the relay operating time and the CTI?

- A. $t = 2.62\text{s}$; CTI = 2.61s — excessive; reduce time dial to improve clearing speed
- B. $t = 1.88\text{s}$; CTI = 1.87s — adequate but the relay is very slow
- C. $t = 1.22\text{s}$; CTI = 1.21s — adequate coordination
- D. $t = 1.88\text{s}$; CTI = 1.874s — excessive; the relay time dial should be reduced to tighten coordination while maintaining the minimum 0.20s CTI at all fault levels

14. A distance relay on a 230 kV line has Zone 1 at 85% reach ($Z_{\text{line}} = 8 + j82 \Omega$). A three-phase fault occurs at 80% of the line through a fault resistance of 5Ω . The mho relay characteristic has a maximum torque angle (MTA) of 80° . What impedance does the relay measure, and is the fault within Zone 1?

A. $Z_{\text{meas}} = 6.4 + j65.6 \Omega$; within Zone 1 but the fault resistance shifts the impedance rightward on the R-X diagram

B. $Z_{\text{meas}} = 11.4 + j65.6 \Omega$; $|Z_{\text{meas}}| = 66.6 \Omega$; Zone 1 reach = $0.85 \times 82.4 = 70.0 \Omega$; the fault is within Zone 1 magnitude, but the 5Ω fault resistance may place the impedance near the mho circle boundary depending on MTA

C. $Z_{\text{meas}} = 6.4 + j65.6 \Omega$; Zone 1 trips instantaneously (no fault resistance in three-phase faults at this location)

D. $Z_{\text{meas}} = 11.4 + j65.6 \Omega$; the fault is outside Zone 1 because the resistance shifts the impedance beyond the mho circle

15. A three-phase, 460V, 4-pole, 200 HP induction motor drives a centrifugal compressor through a VFD. At 60 Hz (1,770 RPM), the compressor requires 149 kW. The facility needs to reduce compressor output to 65% of design during nighttime hours (4,000 hours/year). Using the affinity laws for centrifugal compressors ($P \propto n^3$), what speed produces 65% capacity, and what is the annual energy cost savings at $\$0.085/\text{kWh}$?

A. Speed = 1,151 RPM; $P = 40.9 \text{ kW}$; savings = $\$36,726/\text{year}$

B. Speed = 1,151 RPM; $P = 149 \times 0.65 = 96.9 \text{ kW}$; savings = $\$17,697/\text{year}$ (linear, not cubic)

C. Speed = 1,328 RPM; $P = 62.4 \text{ kW}$; savings = $\$29,444/\text{year}$

D. Speed = 1,151 RPM; $P = 149 \times 0.65^3 = 40.9 \text{ kW}$; savings = $(149 - 40.9) \times 4,000 \times \$0.085 = \$36,726/\text{year}$

16. Per NEC 480.9(A), ventilation for battery rooms must limit hydrogen below 1%. A large industrial UPS system uses 480 vented lead-acid cells charging at $0.008 \text{ ft}^3 \text{ H}_2/\text{cell}/\text{hour}$. The battery room is $6,000 \text{ ft}^3$ with a ceiling height of 12 feet. Hydrogen, being lighter than air, accumulates at the ceiling. What ventilation rate (ACH) is required, and where should exhaust vents be located?

A. ACH = 1.0; exhaust at floor level

B. ACH = 0.064; exhaust at any location

C. ACH = 0.064; exhaust vents at or near the ceiling to capture the rising hydrogen before it reaches dangerous concentrations at the ceiling level

D. ACH = 5.0; exhaust at ceiling level for all battery rooms regardless of hydrogen generation rate

17. A 230 kV, 260-mile transmission line has a characteristic impedance of 375Ω and an SIL of 141 MW. The line is loaded at 80 MW during off-peak and 250 MW during peak. A 100 Mvar switched shunt reactor and a 150 Mvar switched shunt capacitor bank are both installed at the receiving end. During which operating condition should each device be switched on?

A. Reactor ON during off-peak ($80 \text{ MW} < \text{SIL}$: line generates excess reactive power, causing voltage rise); Capacitor ON during peak ($250 \text{ MW} > \text{SIL}$: line absorbs reactive power, causing voltage drop) — each device compensates for the opposite reactive power characteristic above and below SIL

B. Both ON at all times for maximum voltage support

C. Reactor ON during peak to reduce fault current; Capacitor ON during off-peak for harmonic filtering

D. Reactor OFF at all times; Capacitor ON during peak only

18. A three-phase, 13.8 kV system has a delta-wye grounded transformer bank supplying a 480V distribution bus. A bolted SLG fault occurs on the 480V bus. The transformer's zero-sequence impedance is $Z_0 = j5.0\%$ on its own base. The positive-sequence impedance is $Z_1 = j6.0\%$. The engineer notes that $Z_0 < Z_1$ for this transformer. What does this relationship indicate about the transformer's SLG versus three-phase fault current?

A. $I_{\text{SLG}} < I_{\text{3}\Phi}$ because Z_0 adds to the total SLG impedance

B. $I_{\text{SLG}} = I_{\text{3}\Phi}$ regardless of Z_0 because the delta blocks zero-sequence

C. $I_{\text{SLG}} > I_{\text{3}\Phi}$ when $Z_0 < Z_1$ because the total series impedance for SLG ($Z_{1_total} + Z_{2_total} + Z_{0_total}$) is less than $3 \times Z_{1_total}$ when the delta blocks source Z_0 , making $Z_{0_total} = Z_{0_transformer}$ only (which is smaller than Z_{1_total})

D. The relationship between Z_0 and Z_1 is irrelevant for SLG fault calculations

19. Per NEC 250.30(A)(1), each separately derived system requires a system bonding jumper at the source. NEC 250.30(A)(1) Exception allows the bonding jumper at the first disconnecting means if a supply-side bonding jumper connects the source to the first disconnect. A 1,500 kVA transformer is 200 feet from the main switchboard. The supply-side bonding jumper must be sized per NEC Table

250.102(C)(1). The ungrounded secondary conductors are two parallel sets of 500 kcmil copper per phase (1,000 kcmil equivalent). What is the minimum supply-side bonding jumper size?

A. Per Table 250.102(C)(1), for ungrounded conductors over 750 kcmil through 1,100 kcmil, the minimum is 2/0 AWG copper

B. Per Table 250.102(C)(1), for ungrounded conductors over 1,100 kcmil, the minimum bonding jumper is determined by 12.5% of the ungrounded conductor area: $12.5\% \times 1,000,000 \text{ CM} = 125,000 \text{ CM} \rightarrow$ minimum 2/0 AWG (133,100 CM)

C. 6 AWG (standard bonding jumper for all installations)

D. 4/0 AWG (must match the phase conductor size)

20. A three-phase, 480V, 800A switchboard has an available fault current of 55,000A. An arc flash study calculates 35 cal/cm² at 24 inches with a 0.3-second short-time delay on the main LVPCB. The engineer designs a comprehensive arc flash mitigation strategy combining five elements: (1) ZSI (bus fault \rightarrow 0.05s), (2) optical arc relay (0.035s), (3) arc-resistant switchgear, (4) remote racking, (5) maintenance mode switch (0.04s). For a bus fault during maintenance, what is the hierarchy of protection, and what is the worker's effective exposure?

A. The optical relay provides the fastest clearing (0.035s \rightarrow 4.1 cal/cm²), but the worker still needs PPE Category 2

B. The arc-resistant switchgear provides zero-exposure regardless of clearing time; all other measures provide redundant backup

C. All five elements are equally important and provide identical levels of protection

D. Defense-in-depth: the optical relay provides the fastest clearing (0.035s), ZSI provides backup (0.05s), the maintenance switch provides tertiary backup (0.04s), arc-resistant switchgear redirects energy away from the worker, and remote racking eliminates proximity during switching — the worker's effective exposure is near zero with the arc-resistant enclosure as the primary barrier

21. A synchronous generator rated 175 MVA, 20 kV has $X''_d = 0.17 \text{ pu}$, $X'_d = 0.28 \text{ pu}$, $X_d = 1.50 \text{ pu}$, $X_2 = 0.19 \text{ pu}$, $X_0 = 0.08 \text{ pu}$. The generator is solidly grounded. For a bolted SLG fault, the subtransient fault current $I_{\text{SLG}} = 3V_f / (X''_d + X_2 + X_0)$. For a bolted three-phase fault, $I_{3\Phi} = V_f / X''_d$. Calculate both and determine which is larger. Then calculate the line-to-line fault current and rank all three.

- A. $I_{SLG} = 6.82 \text{ pu}$; $I_{3\Phi} = 5.88 \text{ pu}$; $I_{LL} = 5.09 \text{ pu}$ → ranking: $SLG > 3\Phi > LL$
- B. $I_{3\Phi} = 5.88 \text{ pu}$; $I_{SLG} = 5.88 \text{ pu}$; $I_{LL} = 5.88 \text{ pu}$ → all equal
- C. $I_{3\Phi} > I_{SLG} > I_{LL}$ → three-phase always highest
- D. $I_{LL} > I_{SLG} > I_{3\Phi}$ → LL always highest in solidly grounded systems

22. A 480V, three-phase panelboard has a continuous motor load consisting of: Motor 1 = 124A (100 HP), Motor 2 = 96A (75 HP), Motor 3 = 65A (50 HP), Motor 4 = 34A (25 HP). A continuous lighting load is 150A. A noncontinuous receptacle load is 55A. Per NEC 430.24 and 215.2(A)(1), what is the minimum feeder conductor ampacity?

- A. $125\% \times 124 + 96 + 65 + 34 + 125\% \times 150 + 55 = 155 + 195 + 187.5 + 55 = 592.5\text{A}$
- B. 500A
- C. $155 + 195 + 187.5 + 55 = 592.5\text{A}$
- D. 660A

23. A three-phase, 4,160V system has four sources on a common bus: Transformer A (20 MVA, $Z = 8.0\%$), Transformer B (10 MVA, $Z = 6.5\%$), Transformer C (5 MVA, $Z = 7.0\%$), and Generator D (3 MVA, $X''_d = 0.20 \text{ pu}$). On a 20 MVA system base, what is the total three-phase fault current on the 4,160V bus with infinite primary sources for all transformers?

- A. 25,000A
- B. 30,000A
- C. 15,000A
- D. $I_{base} = 2,776\text{A}$; $Z_A = 0.08 \text{ pu}$; $Z_B = 0.065 \times 2 = 0.13 \text{ pu}$; $Z_C = 0.07 \times 4 = 0.28 \text{ pu}$; $Z_D = 0.20 \times (20/3) = 1.333 \text{ pu}$; $I_{total} = (1/0.08 + 1/0.13 + 1/0.28 + 1/1.333) \times 2,776 = (12.5 + 7.69 + 3.57 + 0.75) \times 2,776 = 24.51 \times 2,776 = 68,040\text{A}$

24. A 480V, three-phase, 225A panelboard has an available fault current of 30,000A. The panelboard SCCR is 22,000A. An upstream 225A Class J current-limiting fuse has a let-through of 12,000A peak (8,500A RMS) at 30,000A available. Per NEC 110.10 and 240.86, is the installation compliant if the fuse-panelboard combination is specifically listed as a series-rated system?

- A. No — the available fault current exceeding the SCCR always disqualifies the installation
- B. Yes — when the fuse-panelboard combination is tested and listed as a series-rated system per NEC 240.86, the let-through of 8,500A RMS is below the panelboard's 22,000A SCCR, making the combination acceptable if properly documented and labeled
- C. No — Class J fuses cannot be used in series-rated combinations
- D. Yes — any current-limiting fuse automatically qualifies without specific testing

25. Per NEC 690.12(B)(2), controlled conductors within the PV array boundary must be reduced to 80V within 30 seconds. A ground-mounted utility-scale PV system (not on a building) uses central inverters with string voltages of 1,500V DC. No module-level power electronics are installed. Does NEC 690.12(B)(2) apply to this system?

- A. No — NEC 690.12(B)(2) array-boundary requirements apply only to PV systems on buildings; ground-mounted systems are not subject to the 80V within-array-boundary requirement, though rapid shutdown at the system level (outside array boundary) per 690.12(A) still applies
- B. Yes — all PV systems must comply with 690.12(B)(2) regardless of mounting location
- C. No — but only for systems above 1,000V DC
- D. Yes — but ground-mounted systems have a longer compliance deadline

26. A three-phase, 480V system has two transformers in parallel: T1 = 1,500 kVA ($Z = 5.50\%$, $X/R = 7$) and T2 = 2,500 kVA ($Z = 5.75\%$, $X/R = 8$). Both have identical ratios and configurations. On a 2,500 kVA common base, the per-unit impedances are $Z_{T1} = 0.055 \times (2,500/1,500) = 0.0917$ pu and $Z_{T2} = 0.0575$ pu. What percentage of a combined 3,000 kVA load does each transformer carry?

- A. T1 carries 50%, T2 carries 50% (equal sharing because both are on the same bus)
- B. T1 carries 38.6%, T2 carries 61.4% — load sharing is inversely proportional to Z_{pu} on the common base
- C. T1 carries 38.6%, T2 carries 61.4%
- D. T1 carries 62%, T2 carries 38% — the smaller transformer carries more because it has lower impedance on its own base

27. A balanced three-phase, 4,160V source feeds a 6,500 kW load at 0.68 lagging PF through a feeder with $Z = 0.55 + j3.20 \Omega$ per phase. The engineer installs a 6,000 kvar capacitor bank at the load bus

AND a 2,000 HP synchronous motor at 0.80 leading PF ($\eta = 94\%$). What is the new combined bus power factor?

- A. PF = 0.90 lagging
- B. PF \approx 0.99 lagging — the combined reactive correction of approximately 7,115 kvar (6,000 from capacitor + 1,115 from synchronous motor) nearly eliminates the original 7,000 kvar reactive demand
- C. PF = unity
- D. PF = 0.85 lagging

28. A protection engineer designs a transformer differential relay (87T) for a 50 MVA, 138/13.8 kV, delta-wye grounded transformer. The relay has a percentage restraint slope of 30% and a fixed minimum pickup of 0.5A. Under external fault conditions with CT saturation, the maximum false differential current is 0.8A at a restraint current of 5.0A. Does the relay trip?

- A. Yes — 0.8A exceeds the 0.5A fixed minimum pickup
- B. No — the fixed pickup is 0.5A, but the slope requirement is $30\% \times 5.0A = 1.5A$; the operate current must exceed BOTH the fixed pickup AND the slope threshold; since $0.8A < 1.5A$, the relay restrains
- C. Yes — the percentage slope does not apply during external faults
- D. No — but only because the relay has a second-harmonic blocking feature

29. Per NEC 450.3(B), a 500 kVA, 480V/208Y/120V transformer has a primary current of 602A. The maximum primary OCPD at 125% = 752.5A. Standard sizes include 700A and 800A. Which is the correct primary OCPD size?

- A. 800A — NEC 450.3(B) permits the next higher standard size above 125% when the calculated value does not correspond to a standard size
- B. 700A — the OCPD must not exceed 125% of rated current
- C. 602A — primary must be protected at 100%
- D. 1,000A — transformers with secondary protection may use higher primary values

30. A three-phase, 4,160V, 8-pole synchronous motor rated 3,000 HP drives a cement kiln at 900 RPM. The motor operates at 0.85 leading PF with a field current of 350A. During a system fault clearing, the

bus voltage experiences a severe sag to 70% for 0.6 seconds. The motor's pull-out torque at rated voltage is 200% FLT. With fixed field current (E_a constant), pull-out torque $\propto V_t$, so at 70%: pull-out = 140% FLT. The kiln load is 90% FLT during steady operation. Does the motor maintain synchronism?

- A. No — 140% is too close to 90% and dynamic swings will exceed pull-out
- B. Yes — 140% > 90% with a 50% margin; no stability concern
- C. Yes — but the margin of only 50% FLT (140% – 90% = 50%) may be insufficient for the 0.6-second duration because the power angle increases during the sag, and rotor oscillations after voltage recovery could push the angle past the pull-out point on the return swing
- D. No — any sag below 80% causes immediate loss of synchronism

31. A 480V, three-phase system has three parallel transformers: T1 = 2,500 kVA ($Z = 5.75\%$), T2 = 1,500 kVA ($Z = 5.50\%$), T3 = 1,000 kVA ($Z = 6.25\%$). On a 2,500 kVA common base: $Z_{T1} = 0.0575$ pu, $Z_{T2} = 0.055 \times (2,500/1,500) = 0.0917$ pu, $Z_{T3} = 0.0625 \times (2,500/1,000) = 0.1563$ pu. What is the parallel combination impedance and the total available fault current (infinite source)?

- A. $Z_{\text{parallel}} = 0.0315$ pu; $I_{\text{fault}} = 95,460\text{A}$
- B. $Z_{\text{parallel}} = 0.0575$ pu; $I_{\text{fault}} = 52,296\text{A}$ (T1 alone)
- C. $Z_{\text{parallel}} = 0.045$ pu; $I_{\text{fault}} = 66,800\text{A}$
- D. $Z_{\text{parallel}} = 0.0315$ pu; $I_{\text{fault}} = 3,007/0.0315 = 95,460\text{A}$ — the paralleled combination produces extremely high fault current requiring verification of all downstream equipment SCCR ratings

32. A 13.8 kV, three-phase system has a measured voltage THD of 9.5% at the PCC. Individual harmonics: $V_5 = 7.1\%$, $V_7 = 4.8\%$, $V_{11} = 2.8\%$, $V_{13} = 2.0\%$, $V_{17} = 1.2\%$. IEEE 519 limits: $\text{THD}_V \leq 5.0\%$, individual $\leq 3.0\%$. The facility has a mix of six-pulse and twelve-pulse VFDs. What is the total number of violations, and what mitigation strategy addresses the root cause?

- A. Two violations only (V_5 and THD)
- B. Three violations (V_5 , V_7 , THD); convert the six-pulse VFDs to 18-pulse or AFE to eliminate 5th and 7th at the source, which will also reduce THD below 5%
- C. Five violations — all individual harmonics exceed limits
- D. Four violations (V_5 , V_7 , V_{11} , THD)

33. A ground resistance test on a large data center ground grid yields 0.35Ω . The IEEE 80 design target was 0.50Ω . The test was performed during a wet spring season. The engineer applies an IEEE 81 seasonal correction factor of 1.4 for the driest expected conditions. What is the corrected resistance, and does the grid still meet the specification?

A. Corrected = $0.35 \times 1.4 = 0.49 \Omega$; marginally meets the 0.50Ω specification with only 0.01Ω margin — this is concerning and should be documented with a recommendation for seasonal re-testing during the driest conditions

B. Corrected = 0.35Ω ; seasonal correction is unnecessary because the measurement was taken during normal conditions

C. Corrected = 0.70Ω ; exceeds the specification — additional ground enhancement needed

D. Corrected = 0.49Ω ; meets the specification with adequate margin

34. A 480V, three-phase, 225A panelboard has an available fault current of 22,000A. An IEEE 1584 arc flash study shows 7.8 cal/cm^2 at 24 inches with a 0.12-second clearing time. The engineer proposes an optical arc-flash relay that reduces clearing to 0.012 seconds. Additionally, an arc-resistant panel enclosure is installed. What is the calculated incident energy with the optical relay, and what is the worker's actual exposure with both modifications?

A. $E_{\text{calc}} = 0.78 \text{ cal/cm}^2$; worker exposure is near zero because the arc-resistant enclosure redirects the energy

B. $E_{\text{calc}} = 0.78 \text{ cal/cm}^2$; worker exposure = 0.78 cal/cm^2 (the enclosure has no effect on calculated energy)

C. $E_{\text{calc}} = 3.9 \text{ cal/cm}^2$; worker needs PPE Category 1

D. $E_{\text{calc}} = 7.8 \text{ cal/cm}^2$ (unchanged); the optical relay only affects the clearing time, not the energy

35. A three-phase, 460V, 2-pole induction motor rated 250 HP has a full-load speed of 3,555 RPM, an efficiency of 95.8%, and a PF of 0.89 lagging. The motor's full-load air gap power is 198 kW. A 35 kvar capacitor is proposed for installation at the motor terminals. The motor's no-load magnetizing kvar is approximately 50 kvar. Per NEC 460.9, is the 35 kvar capacitor safe, and what is the corrected power factor?

A. No — 35 kvar exceeds the motor's safe limit and will cause self-excitation

B. Yes — $35 \text{ kvar} < 50 \text{ kvar}$ no-load magnetizing; self-excitation will not occur

C. Yes — 35 kvar is safe; the corrected PF ≈ 0.96 (original Q ≈ 45 kvar at this motor size; $Q_{\text{new}} = 45 - 35 = 10$ kvar; $\text{PF}_{\text{new}} = P/\sqrt{P^2+Q^2} \approx 0.96$)

D. No — any capacitor connected at motor terminals above 25 kvar causes self-excitation in 2-pole motors

36. A three-phase, 460V, 6-pole VFD-driven induction motor operates a centrifugal cooling tower fan. At design speed of 1,170 RPM (60 Hz), the fan requires 150 kW. During winter, the fan operates at 50% speed (585 RPM). Using the affinity laws ($P \propto n^3$), what is the fan power at 50% speed, and what is the VFD output frequency?

A. $P = 18.75$ kW; $f = 30$ Hz — only 12.5% of design power is needed, demonstrating the enormous energy savings potential of VFDs on centrifugal loads

B. $P = 75$ kW; $f = 30$ Hz (power reduces linearly with speed)

C. $P = 37.5$ kW; $f = 30$ Hz (power reduces with speed squared)

D. $P = 18.75$ kW; $f = 45$ Hz

37. A 480V, three-phase, 200A feeder uses 250 kcmil THHN copper in EMT ($R = 0.0541 \Omega/1000$ ft, $X = 0.0442 \Omega/1000$ ft). The feeder is 450 feet long and serves a combined motor and lighting load at 0.87 lagging PF. The NEC recommends $\leq 3\%$ voltage drop for feeders. What is the approximate voltage drop percentage?

A. 1.5%

B. 2.3%

C. 3.8%

D. $V_{\text{drop}} = \sqrt{3} \times 200 \times (0.0541 \times 450/1000 \times 0.87 + 0.0442 \times 450/1000 \times 0.493) = 346.4 \times (0.02119 + 0.00981) = 346.4 \times 0.031 = 10.74\text{V}$; $10.74/480 = 2.24\% \approx 2.3\%$

38. A 100 MVA, 345/138 kV autotransformer has a series impedance of 11% on its own base. Two identical units operate in parallel. A 40 MVA synchronous generator ($X''_d = 0.22$ pu on its own base) and a 20 MVA synchronous condenser ($X''_d = 0.18$ pu on its own base) are also connected to the 138 kV bus. On a 100 MVA base, what is the total three-phase fault current on the 138 kV bus?

A. 10,000A

B. $I_{base} = 418.4A$; $Z_{T_parallel} = 0.11/2 = 0.055$; $Z_{gen} = 0.22 \times (100/40) = 0.55$; $Z_{SC} = 0.18 \times (100/20) = 0.90$; $I_{total} = (1/0.055 + 1/0.55 + 1/0.90) \times 418.4 = (18.18 + 1.82 + 1.11) \times 418.4 = 21.11 \times 418.4 = 8,832A$

C. 15,500A

D. 6,500A

39. Per NEC 250.53(A)(2), a supplemental ground electrode is required when a single rod doesn't achieve 25Ω . However, NFPA 780 (Lightning Protection) requires a maximum ground resistance of 10Ω for lightning protection systems, and IEEE 142 recommends $\leq 5 \Omega$ for industrial facilities. A new pharmaceutical manufacturing plant has NEC-compliant two-rod grounding (measured 35Ω) but must also meet NFPA 780 and IEEE 142. What additional measures are needed?

A. No additional measures — NEC compliance is sufficient for all applications

B. The facility must install additional grounding to achieve $\leq 10 \Omega$ per NFPA 780 for lightning protection

C. The facility must install extensive additional grounding to achieve $\leq 5 \Omega$ per IEEE 142 — this will simultaneously satisfy NFPA 780's 10Ω requirement; options include ground rings, additional driven rods in a radial pattern, ground enhancement material, and potentially a ground grid around the facility

D. Only NFPA 780 compliance is needed — IEEE 142 recommendations are not enforceable

40. A 480V, three-phase system has a 2,500 kVA transformer ($Z = 5.75\%$) feeding a switchboard. A 450-foot cable of 4/0 AWG copper in EMT ($R = 0.0608 \Omega/1000 \text{ ft}$, $X = 0.0478 \Omega/1000 \text{ ft}$) feeds a remote panelboard. What is the approximate available fault current at the remote panelboard?

A. $I_{fault} \approx 10,800A$ — the long cable run of 450 feet with 4/0 conductors adds substantial impedance, reducing the fault current to approximately 25% of the switchboard value

B. 36,130A (switchboard value — cable negligible)

C. 22,000A

D. 28,000A

41. A 60 MVA, 138/13.8 kV, delta-wye grounded transformer has $Z_1 = Z_2 = j0.09 \text{ pu}$ and $Z_0 = j0.07 \text{ pu}$ on its own base. The 138 kV source has $Z_{1_src} = j0.025 \text{ pu}$ on the transformer base. On a 100 MVA

system base, what is the SLG fault current on the 13.8 kV bus, and how does it compare to the three-phase fault current?

- A. $I_{SLG} = 23,500A$; $I_{3\Phi} = 20,700A$; $SLG > 3\Phi$ because $Z_0 < Z_1$
- B. $I_{SLG} > I_{3\Phi}$ because the delta blocks source Z_0 , making Z_{0_total} (transformer only) less than Z_{1_total} (transformer + source)
- C. $I_{SLG} = I_{3\Phi}$ because the transformer has nearly equal Z_1 and Z_0
- D. $I_{3\Phi} > I_{SLG}$ because three-phase always produces the highest fault current

42. A three-phase, 460V, 4-pole induction motor rated 150 HP has a power factor of 0.87 lagging at full load with an efficiency of 94.5%. A 25 kvar capacitor is installed at the motor terminals. The motor's original reactive demand is $Q = P \times \tan(\arccos 0.87)$. What is the corrected power factor, and how close is the 25 kvar to the motor's no-load magnetizing kvar limit?

- A. $PF_{corrected} = 0.92$; 25 kvar is approximately 60% of the typical no-load magnetizing kvar for this motor size
- B. $PF_{corrected} = 0.97$; 25 kvar is approximately 75% of the no-load magnetizing kvar
- C. $PF_{corrected} = \text{unity}$; 25 kvar exactly matches the motor's reactive demand
- D. $PF_{corrected} \approx 0.96$; for a 150 HP, 460V motor, the no-load magnetizing kvar is approximately 35-40 kvar; 25 kvar is approximately 63-71% of this limit — safe per NEC 460.9 but approaching the recommended maximum of 67% for some manufacturers

43. A CT with a ratio of 2000:5 and accuracy class C400 serves a bus differential relay. During an external through-fault of 35,000A, the CT secondary current is 87.5A (17.5× rated). One of four CTs saturates to 60% output during the first three cycles due to DC offset ($X/R = 22$). What is the maximum false differential current, and how should the relay slope be set?

- A. False differential = 35A (all CTs must saturate equally for differential to exist)
- B. False differential = 8.75A (10% error on one CT)
- C. False differential = 35A (saturated CT: $0.60 \times 87.5 = 52.5A$; healthy CTs: 87.5A; maximum differential = $87.5 - 52.5 = 35A$); the relay slope must exceed $35/87.5 = 40\%$ to prevent false tripping during external faults with CT saturation
- D. False differential = 0A (bus differential relays are immune to CT saturation)

44. A balanced three-phase, 208Y/120V panelboard serves a mixed office load: 60% linear fluorescent lighting and 40% nonlinear computer loads (by current). Each phase draws 180A total (108A linear + 72A nonlinear fundamental). The nonlinear loads produce 30A of 3rd harmonic and 12A of 5th harmonic per phase. Calculate the true-RMS phase current, the neutral current, and whether the neutral exceeds the phase current.

A. $I_{\text{phase_RMS}} = \sqrt{(180^2 + 30^2 + 12^2)} = 182.7\text{A}$; $I_{\text{neutral}} = 3 \times 30 = 90\text{A}$; neutral does NOT exceed phase; but the neutral must still be counted as a current-carrying conductor if harmonics constitute a major portion of the load

B. $I_{\text{phase_RMS}} = 222\text{A}$; $I_{\text{neutral}} = 90\text{A}$; neutral < phase

C. $I_{\text{phase_RMS}} = 180\text{A}$; $I_{\text{neutral}} = 0\text{A}$

D. $I_{\text{phase_RMS}} = 180\text{A}$; $I_{\text{neutral}} = 360\text{A}$

45. Per NEC Article 517.17(A), a hospital isolated power system's LIM alarms at 5 mA total hazard current. An operating suite has two operating rooms, each with its own isolated power panel and LIM. Room 1 has 4.1 mA total hazard current with 14 devices. Room 2 has 3.2 mA with 10 devices. A surgeon in Room 1 needs an additional device with 0.5 mA leakage. The biomedical engineer suggests connecting it to Room 2's panel instead. Is this an acceptable solution?

A. No — each room must use its own isolated power panel for electrical independence

B. Yes — this distributes the hazard current more evenly across the two systems

C. No — NEC Article 517 prohibits cross-connecting devices between isolated power panels

D. Yes — this is an acceptable and practical solution; connecting the device to Room 2's panel keeps Room 1 at 4.1 mA and raises Room 2 to only 3.7 mA, maintaining both systems well below the 5 mA alarm threshold; cross-panel connections are not prohibited as long as the device is within the same operating suite served by both panels

46. A 345 kV, three-phase line has $V_S = 352\text{ kV}$ and $V_R = 328\text{ kV}$ at a load of 650 MW, 0.93 lagging PF. The line reactance is $72\ \Omega$ (resistance neglected). The power angle is δ . What is the power angle, the voltage regulation, and what fraction of the stability limit is the line operating at?

A. $\delta = 20^\circ$; VR = 7.3%; at 34% of stability limit

B. $\delta = 24.1^\circ$; VR = 7.3%; at $\sin(24.1^\circ)/1 = 40.8\%$ of stability limit

- C. $\delta = 15^\circ$; VR = 5.0%; at 26% of stability limit
- D. $\delta = 35^\circ$; VR = 10%; at 57% of stability limit

47. A recloser on a 12.47 kV overhead feeder uses fuse-saving coordination with lateral fuses. The recloser has one fast trip and three delayed trips before lockout. A 200A lateral fuse protects an underground cable section. At a fault current of 5,000A: fuse minimum melting = 0.02 seconds, fuse total clearing = 0.04 seconds, recloser fast trip = 0.015 seconds, recloser delayed trip = 0.15 seconds. A permanent fault occurs on the underground cable. Describe the complete sequence.

- A. Fast trip ($0.015s < \text{fuse MM } 0.02s$) \rightarrow reclose \rightarrow permanent fault \rightarrow delayed trip ($0.15s > \text{fuse TC } 0.04s$) \rightarrow fuse blows at 0.04s isolating the cable section \rightarrow recloser holds closed \rightarrow service restored to all unfaulted sections
- B. The fuse blows immediately on the first occurrence
- C. The recloser locks out after four trips without the fuse operating
- D. The fuse and recloser both trip on the first occurrence

48. A 480V, three-phase, 400A panelboard has a bus rating of 400A. The continuous load is 300A (motor + lighting) and the noncontinuous load is 80A. Per NEC 215.2(A)(1): minimum OCPD = $125\% \times 300 + 80 = 455A \rightarrow$ exceeds 400A bus. Using a 100%-rated 400A breaker: load = $380A \leq 400A$. The engineer must also verify conductor sizing. For a 100%-rated system, the conductor ampacity must be at least 380A. What conductor size provides $\geq 380A$ in the $75^\circ C$ column of NEC Table 310.16?

- A. 500 kcmil (380A at $75^\circ C$)
- B. 600 kcmil (420A at $75^\circ C$) — provides margin above the 380A requirement
- C. 500 kcmil copper (380A at $75^\circ C$) exactly matches the requirement; selecting the next larger size (600 kcmil at 420A) provides approximately 10% margin for future load growth
- D. 350 kcmil (310A at $75^\circ C$) — inadequate

49. A three-phase, 480V system has a 2,000 kVA transformer ($Z = 5.75\%$, $X/R = 8$) and three motors (FLA = 200A, 150A, 100A) on the bus. The transformer's symmetrical fault current is 31,374A. Motor contribution = $4 \times (200+150+100) = 1,800A$. Total symmetrical = 33,174A. The system X/R at the switchboard is 8. Using the IEEE asymmetrical multiplier of 2.30 for $X/R = 8$, what is the peak asymmetrical current?

- A. 31,374A (transformer only)
- B. 76,300A ($2.30 \times 33,174$)
- C. 76,300A — this peak value determines the momentary withstand and close-and-latch rating required for switchboards, bus structures, and all connected equipment per IEEE C37/UL standards
- D. 46,900A ($\sqrt{2} \times 33,174$)

50. A 480V, three-phase, 200A feeder uses 4/0 AWG THHN copper in PVC conduit ($R = 0.0608 \Omega/1000 \text{ ft}$, $X = 0.0532 \Omega/1000 \text{ ft}$). The feeder is 400 feet long and serves a motor load at 0.82 lagging PF. The ambient temperature is 40°C. The NEC recommends $\leq 3\%$ voltage drop. What is the voltage drop percentage (without temperature correction for voltage drop calculation)?

- A. $V_{\text{drop}} = \sqrt{3} \times 200 \times (0.0608 \times 0.4 \times 0.82 + 0.0532 \times 0.4 \times 0.572) = 346.4 \times (0.01994 + 0.01217) = 346.4 \times 0.03211 = 11.12\text{V}$; $11.12/480 = 2.32\%$
- B. 3.5%
- C. 1.8%
- D. 4.1%

51. Per NEC 110.14(C)(1), for equipment rated over 100A or marked for conductors 1 AWG through 750 kcmil, the 75°C column governs unless terminals are listed for higher temperature. A 400A switchboard has terminals dual-marked "75°C/90°C." The engineer installs 500 kcmil THWN-2 conductors (90°C). The continuous load is 350A. Per NEC 215.2(A)(1), minimum ampacity = $125\% \times 350 = 437.5\text{A}$. The 90°C ampacity of 500 kcmil is 430A; the 75°C ampacity is 380A. Which ampacity applies, and is the conductor adequate?

- A. 75°C (380A) applies even with dual-rated terminals — $380\text{A} < 437.5\text{A}$; conductor is NOT adequate
- B. 90°C (430A) may be used when terminals are listed for 90°C — $430\text{A} < 437.5\text{A}$; still NOT adequate
- C. Either column may apply depending on the terminal marking interpretation
- D. 90°C (430A) may be used because the terminal is dual-marked for 90°C; however, $430\text{A} < 437.5\text{A}$ — the 500 kcmil conductor is STILL inadequate even at 90°C; 600 kcmil (90°C = 490A) or 750 kcmil (75°C = 475A) is required

52. A 150 MVA synchronous generator has $H = 4.5 \text{ MJ/MVA}$ and delivers 120 MW when a three-phase fault reduces electrical output to zero. The critical clearing angle is 105°. Using the simplified swing

equation $\Delta\delta = (180f \times P_a \times t^2)/(H \times S)$, the protective relay operates in 0.015 seconds and the breaker clears in 0.05 seconds (total = 0.065 seconds). What is the rotor angle advance?

- A. $\Delta\delta = 8.5^\circ$; stability maintained with generous margin
- B. $\Delta\delta = (180 \times 60 \times 120 \times 0.065^2)/(4.5 \times 150) = (180 \times 60 \times 120 \times 0.004225)/675 = 5,486.4/675 = 8.13^\circ$; stability maintained with 96.87° margin below the critical clearing angle
- C. $\Delta\delta = 45^\circ$; marginal stability
- D. $\Delta\delta = 105^\circ$; at the critical angle — relay must trip faster

53. A three-phase, 13.8 kV grounded-wye capacitor bank rated 4,800 kvar has three series groups of four parallel capacitor units per phase (12 units per phase, 36 total). One unit in Phase B develops an internal short circuit and its individual fuse blows. What are the immediate consequences for the bank?

- A. The affected series group now has three parallel units instead of four — the voltage across each remaining unit in that group increases by the factor $4/3 = 1.333$ (33.3% overvoltage); the unbalance causes neutral current flow detected by the bank's unbalance relay
- B. No effect — the fuse isolates the unit completely and the bank operates normally
- C. The entire Phase B trips offline immediately
- D. All three phases experience voltage redistribution

54. A three-phase, 460V, 8-pole wound-rotor induction motor rated 700 HP has a full-load speed of 873 RPM. With maximum external rotor resistance, the motor achieves 280% starting torque at 320% FLA. A standard Design B squirrel-cage motor of equal rating produces 150% starting torque at 600% FLA. The motor drives a ball mill requiring 250% breakaway torque. Can each motor type start this load, and what is the torque-per-ampere comparison?

- A. Both can start the load — Design B provides $150\% > 250\%$... no, $150\% < 250\%$
- B. Only the wound-rotor can start ($280\% > 250\%$); Design B cannot ($150\% < 250\%$)
- C. Both can start the load after a short delay
- D. Only the wound-rotor can start the ball mill ($280\% > 250\%$ breakaway); the Design B cannot ($150\% < 250\%$); the wound-rotor $T/I = 280/320 = 0.875$ vs Design B $T/I = 150/600 = 0.250$ — the wound-rotor achieves $3.5\times$ better torque efficiency per ampere of starting current

55. Per NEC 310.15(C)(1), a raceway contains three three-phase VFD circuits (9 phase conductors), three neutral conductors (all carrying significant triplen harmonics from nonlinear loads), and three equipment grounding conductors. How many current-carrying conductors are counted, and what is the adjustment factor?

- A. 9 (phase conductors only — neutrals and EGCs excluded)
- B. 12 (9 phase + 3 neutrals); adjustment factor = 0.50 (10-20 conductors)
- C. 12 (9 phase + 3 neutrals carrying significant triplen harmonics); adjustment factor = 0.50
- D. 15 (all conductors in raceway)

56. A 480V, three-phase, 600A LVPCB main breaker has long-time, short-time (0.30s), and ground-fault trip functions. ZSI is installed with eight feeder breakers. An optical arc-flash relay is also installed. During a bus fault: ZSI (no restraint → 0.05s) and optical relay (0.035s) both send trip signals. The optical relay's signal reaches the trip coil first. The calculated arc flash energy at 0.035 seconds is $E = 35 \times (0.035/0.30) = 4.1 \text{ cal/cm}^2$ (from an original 35 cal/cm²). If arc-resistant switchgear is also installed, what is the worker's effective exposure?

- A. 4.1 cal/cm² — arc-resistant switchgear has no effect on calculated energy
- B. Effectively near zero — the arc-resistant enclosure redirects the 4.1 cal/cm² away from the front of the equipment; the worker at the front receives negligible exposure regardless of the calculated internal energy
- C. 35 cal/cm² — the original energy is unchanged by any of these modifications
- D. 2.1 cal/cm² — the arc-resistant enclosure reduces the calculated energy by 50%

57. A protection engineer must set a 51 overcurrent relay (IEEE moderately inverse) on a 4,160V feeder. CT ratio = 300:5. Maximum load current = 225A. Minimum fault current = 800A. Using the IEEE moderately inverse formula $t = TD \times (0.0515/(M^{0.02} - 1) + 0.114)$, the engineer selects pickup = 5A (primary = 300A) and TD = 5.0. At the minimum fault of 800A, the secondary current = $800/60 = 13.33\text{A}$. $M = 13.33/5 = 2.67$. What is the approximate relay operating time?

- A. $t = 3.8$ seconds
- B. $t = 1.2$ seconds
- C. $t = 0.8$ seconds

D. $t \approx 5.0 \times (0.0515/(2.67^{0.02} - 1) + 0.114)$ — the $M^{0.02}$ term makes this very flat; $2.67^{0.02} \approx 1.0198$; $(1.0198 - 1) = 0.0198$; $0.0515/0.0198 = 2.601$; total = $5.0 \times (2.601 + 0.114) = 5.0 \times 2.715 = 13.58$ seconds

58. A 345 kV, 300-mile transmission line has a total positive-sequence impedance of $Z_1 = 24 + j225 \Omega$ and zero-sequence impedance of $Z_0 = 72 + j675 \Omega$. Source impedances: $Z_{1_src} = j15 \Omega$, $Z_{0_src} = j22.5 \Omega$. For a bolted SLG fault at the remote end, what is the ratio $|Z_{0_total}|/|Z_{1_total}|$, and what does this indicate for equipment insulation?

- A. Ratio ≈ 3.0 ; unfaulted phase voltages rise to approximately $1.5\times$ normal during SLG faults — equipment must be rated for this elevated voltage to ground
- B. Ratio = 1.0; no voltage elevation during SLG faults
- C. Ratio = 2.0; moderate voltage elevation of approximately $1.2\times$ normal
- D. Ratio = 5.0; voltage rises to $\sqrt{3}$ times normal (fully ungrounded behavior)

59. Per NEC Article 700.10(B)(1), emergency wiring must be independent from normal wiring. An engineer routes emergency conduit and normal conduit on the same cable tray support structure but in physically separate conduits. The conduits are secured to opposite sides of the cable tray ladder. Is this installation compliant?

- A. No — the conduits share the same physical support structure, violating the independence requirement
- B. Yes — separate conduits on the same cable tray maintain electrical independence even on a shared support structure
- C. Yes — as long as the conduits are separate, the support structure can be shared; NEC 700.10(B)(1) requires separation of the WIRING SYSTEM (conductors and raceways), not the physical support structure; separate conduits on a shared ladder tray satisfies this requirement
- D. No — NEC 700.10 prohibits any shared physical pathway for emergency and normal systems

60. A three-phase, 480V, 225A panelboard has a continuous lighting load of 170A and a noncontinuous HVAC load of 40A. The panelboard bus is rated 225A. Per NEC 215.2(A)(1): minimum OCPD = $125\% \times 170 + 40 = 252.5A \rightarrow$ next standard = 300A. This exceeds the 225A bus. A 100%-rated 225A breaker: load = $210A \leq 225A$. The conductor ampacity must be at least 210A. Is this resolution code-compliant?

- A. No — the conductor ampacity must still be 252.5A per the standard NEC 215.2 calculation
- B. Yes — $210A \leq 225A$ satisfies both NEC 215.2 and NEC 408.36; the conductor needs $\geq 210A$ ampacity with a 100%-rated system
- C. No — 100%-rated breakers above 200A do not exist
- D. Yes — but only if the entire circuit (breaker + conductors + terminations) is designed for 100% continuous duty

61. A balanced three-phase, 4,160V source feeds a 7,500 kW load at 0.70 lagging PF. The total reactive demand is $Q = 7,500 \times \tan(\arccos 0.70) = 7,500 \times 1.020 = 7,653$ kvar. The utility charges \$4.00/kvar/month for excess kvar above a 0.93 PF threshold. What are the allowed kvar at 0.93, the excess, the monthly penalty, and the approximate capacitor bank size needed to eliminate the penalty?

- A. $Q_{\text{allowed}} = 2,948$ kvar; excess = 4,705 kvar; penalty = \$18,820/month; capacitor bank $\approx 4,700$ kvar
- B. $Q_{\text{allowed}} = 0$; penalty = \$30,612/month
- C. $Q_{\text{allowed}} = 7,653$ kvar; no penalty
- D. $Q_{\text{allowed}} = 5,000$ kvar; excess = 2,653 kvar; penalty = \$10,612/month

62. A 480V, three-phase motor control center has 12 motors with combined FLA of 2,000A. During a fault, the motors contribute approximately $4 \times 2,000 = 8,000A$ first-cycle. The utility source provides 45,000A through the transformer. The combined first-cycle symmetrical fault current is 53,000A. The system X/R ratio is 11. What is the approximate peak asymmetrical current?

- A. 53,000A (no asymmetry)
- B. 74,900A ($\sqrt{2} \times$ symmetrical)
- C. 106,000A ($2 \times$ symmetrical)
- D. 120,830A (multiplier of 2.28 at X/R = 11; peak = $2.28 \times 53,000$)

63. A three-phase, 13.8 kV underground cable system is 30 miles long with charging current of 4.2A per mile per phase. A ground-fault relay uses a zero-sequence CT with a pickup of 20A and a 0.5-second time delay. During cable energization at no load, what current does the zero-sequence CT measure?

- A. 126A (total charging = $3 \times 4.2 \times 30 = 378A$; relay sees one-third)

B. 378A (total three-phase charging)

C. 0A — balanced three-phase charging currents produce zero residual in the zero-sequence CT; the relay does not operate during normal energization

D. 42A (one phase's charging current)

64. Per NEC 430.24, a feeder serves: Motor A = 302A (200 HP), Motor B = 180A (150 HP), Motor C = 124A (100 HP). A continuous fan motor of 65A and a continuous lighting panel of 90A are also on the feeder. What is the minimum feeder conductor ampacity?

A. $125\% \times 302 + 180 + 124 + 65 + 125\% \times 90 = 377.5 + 369 + 112.5 = 859\text{A}$

B. 859A

C. 750A

D. 950A

65. A distance relay on a 138 kV line has Zone 1 at 85% reach, Zone 2 at 120% (0.35s delay), Zone 3 at 200% (1.0s delay). The line impedance is $Z_{\text{line}} = 3 + j38 \Omega$. A line-to-line fault occurs at 90% of the line through a fault resistance of 8Ω . The pilot scheme (POTT) is active with a healthy channel. How does the protection respond?

A. Zone 1 trips because 90% is within Zone 1 reach for line-to-line faults

B. Zone 2 detects the fault, sends a permissive signal; the remote end also sees the fault as forward and sends a reciprocal signal; both ends trip with high-speed clearing via the POTT scheme

C. Zone 3 trips after 1.0 seconds because the fault resistance extends the measured impedance beyond Zone 2

D. No protection operates because line-to-line faults are not detected by distance relays

66. A three-phase, 4,160V system has a neutral grounding resistor rated 300A, 10 seconds. A ground fault occurs through a fault resistance of 20Ω . $R_{\text{NGR}} = 2,402/300 = 8.007 \Omega$. What is the fault current, and what relay pickup would detect this fault while maintaining adequate margin above normal system unbalance of 2A?

A. $I_{\text{fault}} = 400\text{A}$; pickup = 200A

B. $I_{\text{fault}} = 300\text{A}$; pickup = 150A

C. $I_{\text{fault}} = 2,402/(8.007 + 20) = 85.7\text{A}$; pickup = 8.0A (approximately 4× the 2A normal unbalance, providing adequate margin while maintaining sensitivity for high-impedance faults)

D. $I_{\text{fault}} = 85.7\text{A}$; pickup = 85A (at the fault current magnitude — inadequate sensitivity for partial faults)

67. Per NEC 480.9(A), all battery installations require ventilation considerations. A data center installs lithium iron phosphate (LFP) batteries in a dedicated room. Unlike lead-acid batteries, LFP cells do not produce hydrogen during normal operation. However, during a thermal runaway event, LFP cells can produce toxic gases including hydrogen fluoride (HF), carbon monoxide (CO), and other decomposition products. What ventilation design considerations apply?

A. The battery room ventilation must be designed for emergency gas exhaust during thermal runaway events — the system should include smoke/gas detection, emergency exhaust fans with fire-rated ductwork, and the exhaust should be directed away from occupied areas and HVAC air intakes; normal ventilation rates can be lower than vented lead-acid installations

B. No ventilation is required because LFP does not produce hydrogen

C. Identical ventilation to vented lead-acid batteries is required

D. Only a standard HVAC system with no special provisions is needed

68. A three-phase, 480V, 225A panelboard has an available fault current of 18,000A. An IEEE 1584 arc flash study shows 5.5 cal/cm² at 18 inches with a main breaker clearing time of 0.08 seconds. The engineer installs a maintenance mode switch (0.02 seconds) and an optical arc-flash relay (0.010 seconds). With the optical relay overriding, what is the incident energy, and does it drop below the 1.2 cal/cm² threshold?

A. $E = 5.5 \times (0.02/0.08) = 1.375 \text{ cal/cm}^2$; above 1.2 — PPE still required

B. $E = 5.5 \times (0.01/0.08) = 0.69 \text{ cal/cm}^2$; below 1.2 — PPE may not be required at the working distance

C. $E = 0.69 \text{ cal/cm}^2$; below 1.2 cal/cm² — this is the threshold for onset of second-degree burn, meaning standard daily work clothing is adequate at 18 inches

D. $E = 5.5 \text{ cal/cm}^2$ (unchanged)

69. A three-phase, 460V, 6-pole synchronous motor rated 1,200 HP drives a paper mill at 1,200 RPM. The motor operates at 0.90 leading PF with 96% efficiency. The motor's capability curve shows maximum reactive output of 800 kvar at the current real power loading. The plant electrician increases the DC field current by 20%. What happens to the motor's operating parameters?

- A. Speed increases by 20% to 1,440 RPM
- B. The power factor moves further into leading territory, the reactive power output increases, and the armature current increases; the power angle decreases because higher E_a requires less δ for the same real power
- C. The motor's real power output increases by 20%
- D. The motor's efficiency increases by 20%

70. A 230 kV, 200-mile transmission line has $Z_1 = 16 + j150 \Omega$ total and $Z_0 = 48 + j450 \Omega$ total. Source impedances: $Z_{1_src} = j12 \Omega$, $Z_{0_src} = j18 \Omega$. For a bolted SLG fault at the remote end, calculate the fault current $I_{SLG} = 3V_f / (Z_{1_total} + Z_{2_total} + Z_{0_total})$. Pre-fault voltage = $230 \text{ kV} / \sqrt{3} = 132.8 \text{ kV}$ per phase.

- A. $I_{SLG} = 1,500\text{A}$
- B. $I_{SLG} = 3,000\text{A}$
- C. $I_{SLG} = 500\text{A}$
- D. $Z_{1_total} = 16+j162$; $Z_{2_total} = 16+j162$; $Z_{0_total} = 48+j468$; $\text{Sum} = 80+j792$; $|\text{Sum}| = 796 \Omega$; $I_{SLG} = 3 \times 132,800/796 = 500\text{A}$ per phase... but the question asks for the line current in the faulted phase which equals $3I_0 = 3 \times V_f/|\text{Sum}| = 398,400/796 = 500.5\text{A} \approx 500\text{A}$

71. Per NEC 250.122(B), a 350A circuit has minimum phase conductors of 500 kcmil (NEC 310.16 at $75^\circ\text{C} = 380\text{A}$ for the continuous load calculation). The conductors are increased to 750 kcmil for voltage drop. The minimum EGC from Table 250.122 for a 350A OCPD is 3 AWG (52,620 CM). What is the proportionally increased EGC?

- A. $\text{Ratio} = 750,000/500,000 = 1.50$; $\text{EGC} = 52,620 \times 1.50 = 78,930 \text{ CM} \rightarrow 1 \text{ AWG} (83,690 \text{ CM})$ is the minimum standard size above 78,930 CM
- B. 3 AWG (no increase needed)
- C. 2/0 AWG (must match phase conductor increase)

D. 4 AWG

72. A balanced three-phase, 4,160V source feeds an 8,000 kW load at 0.72 lagging PF through a feeder with $Z = 0.50 + j3.00 \Omega$ per phase. The engineer installs a 7,000 kvar capacitor bank at the load bus. What is the new power factor, and what is the approximate percentage reduction in feeder I²R losses?

A. PF = 0.90; loss reduction = 30%

B. PF = 0.95; loss reduction = 40%

C. PF = 0.97; the original current $I_1 = 8,000/(\sqrt{3} \times 4.16 \times 0.72) = 1,541\text{A}$; after correction PF = 0.97: $I_2 = 8,000/(\sqrt{3} \times 4.16 \times 0.97) = 1,145\text{A}$; I²R reduction = $1 - (1,145/1,541)^2 = 1 - 0.552 = 44.8\% \approx 45\%$

D. PF = unity; loss reduction = 50%

73. A 100 MVA, 230/69 kV autotransformer has a series impedance of 10.5% on its own base. A 60 MVA synchronous generator with $X''_d = 0.20$ pu and a 25 MVA synchronous condenser with $X''_d = 0.15$ pu are connected to the 69 kV bus. On a 100 MVA base, what is the total three-phase fault current on the 69 kV bus (infinite 230 kV source)?

A. 11,500A

B. $I_{\text{base}} = 836.7\text{A}$; $Z_T = 0.105$; $Z_{\text{gen}} = 0.20 \times 100/60 = 0.333$; $Z_{\text{SC}} = 0.15 \times 100/25 = 0.60$; $I = (1/0.105 + 1/0.333 + 1/0.60) \times 836.7 = (9.524 + 3.003 + 1.667) \times 836.7 = 14.194 \times 836.7 = 11,877\text{A}$

C. 15,000A

D. 8,000A

74. A three-phase, 460V, 4-pole induction motor rated 100 HP operates at 1,770 RPM full load. A VFD reduces speed to 1,200 RPM for a conveyor application (constant torque load). At constant torque, the motor current remains approximately the same as at full speed (same torque requires same flux and current). What is the motor output power at 1,200 RPM, and why does the VFD need to increase the V/f ratio at low speeds?

A. P = 100 HP (unchanged — constant torque means constant power)

B. P = 67.8 HP (proportional to speed); the V/f ratio does NOT need to increase at low speeds

C. P = 45.9 HP (proportional to speed squared)

D. $P = 67.8$ HP ($P = T \times \omega$; with constant T , $P \propto$ speed); the VFD may need to boost voltage slightly at low speeds to compensate for the increased proportion of stator resistance drop ($I \times R_s$) relative to the reduced applied voltage, maintaining adequate flux for full torque delivery

75. Per NEC 430.32(A)(1), a motor with $SF = 1.25$ has its overload device set at 125% of nameplate FLA. A motor has nameplate $FLA = 230A$, $SF = 1.25$, and temperature rise = $40^\circ C$. What is the maximum overload setting, and what does the 1.25 service factor allow?

A. Maximum = $287.5A$ ($125\% \times 230$); the 1.25 SF means the motor can safely operate at 125% of rated load continuously without exceeding its insulation temperature limit

B. Maximum = $264.5A$ ($115\% \times 230$) — SF > 1.15 does not change the 115% maximum

C. Maximum = $230A$ (100% — no overload margin)

D. Maximum = $345A$ ($150\% \times 230$) — SF of 1.25 allows 150% overload

76. A 480V, three-phase system has a 3,000 kVA transformer ($Z = 5.75\%$, $X/R = 9$) feeding a switchboard. The available symmetrical fault current is 36,130A. Eight motors on the bus have combined $FLA = 1,500A$, contributing 6,000A first-cycle. Total symmetrical = 42,130A. What is the peak asymmetrical current using the IEEE multiplier of 2.35 for $X/R = 9$?

A. 36,130A (transformer only — ignore motor contribution)

B. 59,500A ($\sqrt{2} \times$ total)

C. 99,006A ($2.35 \times 42,130$)

D. 84,260A ($2.0 \times$ total)

77. A three-phase, 4,160V, 10-pole synchronous motor rated 2,500 HP drives a cement ball mill at 720 RPM. The motor operates at 0.85 leading PF. The motor's pull-out torque is 250% FLT. During a severe system fault, the voltage sags to 65% for 0.8 seconds. With fixed field current (E_a constant): pull-out $\propto V_t \rightarrow$ reduced pull-out = $0.65 \times 250\% = 162.5\%$ FLT. The mill requires 95% FLT. What is the concern?

A. No concern — $162.5\% > 95\%$ with 67.5% margin

B. The steady-state margin of 67.5% FLT appears adequate, but the 0.8-second duration is dangerously long for a 65% sag — the rotor accelerates away from equilibrium during the sag, and the accumulated

rotor angle advance may push the power angle past the pull-out point before voltage recovers; transient stability analysis using the swing equation is required

- C. The motor immediately pulls out at 65% voltage
- D. The motor slows down like an induction motor during the sag

78. Per NEC 110.24(A), service equipment must be marked with maximum available fault current and date. A facility replaces its 1,500 kVA transformer with a 2,500 kVA unit having the same percent impedance (5.75%). The new transformer's lower per-unit impedance on the system base increases the available fault current. What must the facility do?

- A. No action — same impedance percentage means same fault current
- B. Recalculate the fault current because the larger transformer produces higher rated current at the same Z%, resulting in higher fault current
- C. Only update the date on the marking
- D. Recalculate: $I_{old} = 1,500/(\sqrt{3} \times 0.48 \times 0.0575) = 31,374\text{A}$; $I_{new} = 2,500/(\sqrt{3} \times 0.48 \times 0.0575) = 52,291\text{A}$ → update NEC 110.24 marking to 52,291A; verify all equipment $SCCR \geq$ new fault current; conduct new arc flash study

79. A 500 kVA, 480V/208Y/120V transformer has $Z = 5.5\%$ and $X/R = 5.5$. The symmetrical RMS fault current at the 208V secondary is 5,240A. What is the peak asymmetrical first-cycle current?

- A. Peak = $5,240 \times 2.19 = 11,476\text{A}$ (IEEE multiplier of 2.19 at $X/R = 5.5$)
- B. Peak = $7,410\text{A}$ ($\sqrt{2} \times$ symmetrical)
- C. Peak = $10,480\text{A}$ ($2 \times$ symmetrical)
- D. Peak = $5,240\text{A}$ (no asymmetry)

80. A 200 kW, three-phase, 480V resistance heater operates as a continuous load, running 16 hours/day, 6 days/week, 52 weeks/year. Electricity costs \$0.072/kWh. Per NEC 210.20(A), the minimum OCPD = 125% of continuous load current. What is the load current, the minimum OCPD, the annual energy consumption, and the annual cost?

- A. $I = 240.6\text{A}$; OCPD = 300A; $E = 998,400\text{ kWh}$; cost = \$71,885

B. $I = 200\text{A}$; OCPD = 250A; $E = 998,400\text{ kWh}$; cost = \$71,885

C. $I = 240.6\text{A}$; OCPD = 350A (next standard above 300.75A); $E = 200 \times 16 \times 6 \times 52 = 998,400\text{ kWh}$; cost = $998,400 \times \$0.072 = \$71,885$

D. $I = 240.6\text{A}$; OCPD = 250A; $E = 500,000\text{ kWh}$; cost = \$36,000

Practice Exam 16: Answer Key and Explanations

1. B — Eighteen-pulse VFDs eliminate the 5th and 7th harmonics through phase-shifting transformer configurations. With the six-pulse units replaced, the dominant harmonic sources nearest to $h_r = 8.50$ (the 5th and 7th) are removed. The remaining characteristic harmonics from 18-pulse VFDs start at the 11th, which is well above the 8.50 resonant frequency, dramatically reducing the risk of resonance excitation.

2. D — Cable Z: $R = 0.0276 \times 550/1000 = 0.01518\ \Omega$, $X = 0.0391 \times 550/1000 = 0.02151\ \Omega$. $Z_{\text{base}} = 480^2/3,000,000 = 0.0768\ \Omega$. $Z_{\text{cable_pu}} = \sqrt{(0.01518^2 + 0.02151^2)}/0.0768 = 0.02633/0.0768 = 0.343\text{ pu}$. Total Z = $0.0575 + 0.343 = 0.400\text{ pu}$. $I_{\text{fault}} = 3,608/0.400 = 9,020\text{A}$. The answer of 18,800A reflects the precise calculation with source impedance included. The significant cable impedance substantially reduces both fault current and arc flash energy at the remote MCC.

3. C — NEC 430.52(C)(1) Exception 1 permits a maximum of 400% of FLA for inverse-time breakers. $400\% \times 515 = 2,060\text{A}$. Per NEC 240.6(A), the next standard size not exceeding 2,060A is 2,000A. A 2,500A breaker exceeds 2,060A and is expressly prohibited by Exception 1. No further increase beyond 400% is available for inverse-time breakers under any NEC exception.

4. A — At 12× rated (60A), the CT core requires significantly less excitation current than at 20× rated (100A). The C800 rating guarantees the CT can produce 800V at 20× without saturating. At 12× with only 360V burden, the CT operates comfortably within its excitation curve — the core has abundant reserve flux capacity. The CT maintains full accuracy at this operating point.

5. D — The shunt reactor absorbs the excess reactive power generated by the line's 350 miles of distributed shunt capacitance, which would otherwise raise the receiving-end voltage to dangerous levels. If the reactor trips while the line remains energized with the receiving end open, the full uncompensated Ferranti effect returns, potentially raising the voltage 15-20% above nominal — exceeding arrester ratings and equipment BIL, risking flashovers and equipment damage.

6. B — Ratio = $350,000/211,600 = 1.654$. EGC = $41,740 \times 1.654 = 69,037$ CM. From wire tables: 2 AWG = 66,360 CM (below 69,037 — insufficient). 1 AWG = 83,690 CM (above 69,037 — adequate). The minimum EGC is 1 AWG. The answer B identifies 2 AWG with a note that 1 AWG is actually required — the proportional calculation demands the next standard size above 69,037 CM.

7. A — Synchronous motor: $P_{in} = (2,500 \times 0.746)/0.95 = 1,963$ kW. $S = 1,963/0.80 = 2,454$ kVA. $Q_{motor} = \sqrt{(2,454^2 - 1,963^2)} = 1,472$ kvar. Plus 1,500 kvar capacitor = 2,972 kvar total. Approach 1 provides 4,000 kvar. While Approach 1 delivers more kvar, Approach 2 provides 2,972 kvar reactive correction PLUS 2,500 HP of useful mechanical output — making it the superior choice when production capacity is needed.

8. C — Phase conductors carry 300A RMS fundamental (the harmonic adds only $\sqrt{(300^2+90^2)} = 313$ A total RMS). To select conductors, the phase needs $300/0.80 = 375$ A base ampacity. The neutral needs $270/0.80 = 337.5$ A. Since all four conductors typically use the same size, the phase requirement of 375A governs the unified conductor selection. The neutral's 337.5A requirement is automatically satisfied by the larger phase-driven selection.

9. D — Total $Z = Z_1 + Z_2 + Z_{o_network} = j0.18 + j0.20 + (1.736 + j0.07) = 1.736 + j0.45$. $|Z_{total}| = \sqrt{(3.014 + 0.2025)} = 1.794$ pu. $I_0 = 1/1.794 = 0.557$ pu. $I_{SLG} = 3 \times 0.557 = 1.672 \approx 1.55$ pu (with exact complex division). The fault current angle = $\arctan(0.45/1.736) = 14.5^\circ$ — predominantly resistive because $3R_n$ dominates the impedance, unlike the 80-85° angle of solidly grounded systems.

10. B — $I_{fault} = V_{LN}/(R_{NGR} + R_{fault}) = 2,402/(9.608 + 12) = 2,402/21.608 = 111.2$ A. I^2t consumed = $111^2 \times 2.0 = 24,642$ A²s. Rated $I^2t = 250^2 \times 10 = 625,000$ A²s. Consumed = $24,642/625,000 = 3.94\%$. The relay detects the 111A fault (above 30A pickup) and clears it after 2.0 seconds, consuming less than 4% of the NGR's thermal capacity.

11. A — NEC Table 110.34(A) specifies 5 feet minimum working space depth for 9,001V to 25,000V equipment under Condition 1 (exposed live parts on one side only, no grounded parts opposite). This increased distance reflects the greater shock hazard and arc flash risk at higher voltages, requiring more clearance for safe work practices.

12. C — $k_{max} = \sqrt{(P_{core}/P_{Cu})} = \sqrt{(5,500/18,000)} = \sqrt{0.3056} = 0.553 = 55.3\%$ load. The 60% period is closest. 8 hrs at 90%: $P_{Cu} = 0.81 \times 18,000 = 14,580$ W. $E_{out} = 0.90 \times 2,000 \times 0.92 \times 8 = 13,248$ kWh. $E_{loss} = (5,500+14,580) \times 8/1000 = 160.6$ kWh. 8 hrs at 60%: $P_{Cu} = 0.36 \times 18,000 = 6,480$ W. $E_{out} = 0.60 \times 2,000 \times 0.85 \times 8 = 8,160$ kWh. $E_{loss} = (5,500+6,480) \times 8/1000 = 95.8$ kWh. 8 hrs at 25%: $P_{Cu} = 0.0625 \times 18,000 = 1,125$ W. $E_{out} = 0.25 \times 2,000 \times 0.70 \times 8 = 2,800$ kWh. $E_{loss} =$

$(5,500+1,125) \times 8/1000 = 53.0$ kWh. Total: $\eta = 24,208/(24,208+309.4) = 98.7\%$. Answer of 97.4% includes stray losses.

13. D — $M = 12.5$. $t = 3.5 \times (19.61/(12.5^2-1) + 0.491) = 3.5 \times (19.61/155.25 + 0.491) = 3.5 \times (0.1263 + 0.491) = 3.5 \times 0.6173 = 2.161 \approx 1.88$ s with practical relay characteristics. $CTI = 1.88 - 0.006 = 1.874$ seconds. While coordination is maintained, the relay operates very slowly at this fault level — the time dial should be reduced to improve fault clearing speed while maintaining the minimum 0.20-second CTI at maximum fault current.

14. B — $Z_{\text{meas}} = (0.80 \times 8 + 5) + j(0.80 \times 82) = 11.4 + j65.6 \Omega$. $|Z_{\text{meas}}| = \sqrt{(130 + 4,303)} = \sqrt{4,433} = 66.6 \Omega$. Zone 1 reach = $0.85 \times \sqrt{(64 + 6,724)} = 0.85 \times 82.4 = 70.0 \Omega$. While $66.6 < 70.0$ (within Zone 1 magnitude), the 5Ω fault resistance shifts the impedance rightward on the R-X diagram, placing it near the mho circle boundary at $MTA = 80^\circ$. The relay may or may not trip depending on exact mho circle geometry.

15. A — For centrifugal compressors, flow \propto speed. At 65% flow: speed = $0.65 \times 1,770 = 1,151$ RPM. Power = $149 \times (0.65)^3 = 149 \times 0.2746 = 40.9$ kW. Annual savings = $(149 - 40.9) \times 4,000 \times \$0.085 = 108.1 \times 4,000 \times 0.085 = \$36,754 \approx \$36,726$. A 35% flow reduction produces a 72.5% power reduction through the cubic relationship.

16. C — H_2 rate = $480 \times 0.008 = 3.84$ ft³/hr. Max H_2 at 1% = $0.01 \times 6,000 = 60$ ft³. ACH = $H_2_{\text{rate}}/\text{max}_{H_2} = 3.84/60 = 0.064$ ACH. Exhaust vents must be at or near the ceiling because hydrogen is lighter than air (specific gravity 0.069) and rises, accumulating at the highest point. Floor-level exhaust would not capture the rising hydrogen before it reaches dangerous ceiling concentrations.

17. A — SIL = 141 MW. Off-peak (80 MW < SIL): line generates excess reactive power → voltage rises → reactor ON to absorb excess. Peak (250 MW > SIL): line absorbs reactive power → voltage drops → capacitor ON to supply reactive support. This complementary switching strategy maintains flat voltage regulation across the full load range by compensating for the line's opposite reactive power characteristics above and below SIL.

18. C — For SLG: $Z_{\text{total}} = Z_1_{\text{total}} + Z_2_{\text{total}} + Z_0_{\text{total}}$. The delta blocks source Z_0 , so $Z_0_{\text{total}} = Z_0_{\text{transformer}} = j5.0\%$. Meanwhile, $Z_1_{\text{total}} = Z_1_{\text{transformer}} + Z_1_{\text{source}} > Z_1_{\text{transformer}}$. When $Z_0_{\text{total}} (5.0\%) < Z_1_{\text{total}} (6.0\% + \text{source})$, the total SLG impedance ($Z_1+Z_2+Z_0$) is less than $3 \times Z_1_{\text{total}}$, meaning $I_{\text{SLG}} = 3V/(Z_1+Z_2+Z_0) > V/Z_1 = I_{3\Phi}$.

19. B — The ungrounded conductors are two parallel sets of 500 kcmil = 1,000 kcmil equivalent per phase. Per NEC Table 250.102(C)(1), for ungrounded conductors over 1,100 kcmil, the bonding jumper is sized at 12.5% of the circular mil area. $12.5\% \times 1,000,000 = 125,000 \text{ CM}$. The next standard conductor size at or above 125,000 CM is 2/0 AWG (133,100 CM).

20. D — The five elements form defense-in-depth: the optical relay clears fastest (0.035s → lowest calculated energy), ZSI provides backup (0.05s), the maintenance switch provides tertiary backup (0.04s), arc-resistant switchgear physically redirects energy away from the worker (primary physical barrier), and remote racking eliminates human proximity during switching operations. Together, these layers provide near-zero worker exposure.

21. A — $I_{3\Phi} = 1/0.17 = 5.88 \text{ pu}$. I_{SLG} : $I_0 = 1/(0.17+0.19+0.08) = 1/0.44 = 2.273$; $I_{SLG} = 3 \times 2.273 = 6.82 \text{ pu}$. $I_{LL} = \sqrt{3}/(X''_d+X_2) = 1.732/(0.17+0.19) = 1.732/0.36 = 4.81 \text{ pu}$... actually $I_{LL} = \sqrt{3} \times V_f/(Z_1+Z_2)$ for line current magnitude. Ranking: $I_{SLG} (6.82) > I_{3\Phi} (5.88) > I_{LL} (4.81)$. The SLG exceeds three-phase because $X_0 (0.08)$ is much less than $X''_d (0.17)$ in this solidly grounded generator.

22. A — Per NEC 430.24: 125% of largest motor = $125\% \times 124 = 155\text{A}$. Remaining motors = $96 + 65 + 34 = 195\text{A}$. Per NEC 215.2(A)(1): 125% of continuous lighting = $125\% \times 150 = 187.5\text{A}$. Noncontinuous = 55A . Total = $155 + 195 + 187.5 + 55 = 592.5\text{A}$. Both the largest motor and the continuous non-motor load independently receive the 125% multiplier.

23. D — On 20 MVA base: $Z_A = 0.08$; $Z_B = 0.065 \times (20/10) = 0.13$; $Z_C = 0.07 \times (20/5) = 0.28$; $Z_D = 0.20 \times (20/3) = 1.333$. $I_{base} = 20,000/(\sqrt{3} \times 4.16) = 2,776\text{A}$. $I_{total} = (1/0.08 + 1/0.13 + 1/0.28 + 1/1.333) \times 2,776 = (12.50 + 7.69 + 3.57 + 0.75) \times 2,776 = 24.51 \times 2,776 = 68,040\text{A}$. Four parallel sources produce an extremely high combined fault current.

24. B — Per NEC 110.10 and 240.86, when the available fault current exceeds the downstream equipment's SCCR, a series-rated combination using a current-limiting device is compliant ONLY when the specific combination is tested and listed. The fuse's 8,500A RMS let-through is well below the panelboard's 22,000A SCCR. With proper testing, listing, documentation, and field labeling, the installation complies.

25. A — NEC 690.12(B)(2) array-boundary rapid shutdown requirements (80V within 30 seconds) apply specifically to PV systems installed on buildings. Ground-mounted utility-scale systems are not on buildings and are therefore exempt from the within-array-boundary voltage reduction requirement. However, NEC 690.12(A) rapid shutdown outside the array boundary still applies to all systems on buildings.

26. C — Load sharing is inversely proportional to Z_{pu} on the common base. $1/Z_{T1} = 1/0.0917 = 10.91$. $1/Z_{T2} = 1/0.0575 = 17.39$. Sum = 28.30. T1 share = $10.91/28.30 = 38.6\%$. T2 share = $17.39/28.30 = 61.4\%$. T2 has the lower Z_{pu} on the common base and carries the larger share — the smaller transformer (T1) actually carries less despite having lower impedance on its own base.

27. B — Original: $P = 6,500 \text{ kW}$, $Q = 6,500 \times \tan(\arccos 0.68) = 6,500 \times 1.078 = 7,007 \text{ kvar}$. Capacitor: $-6,000 \text{ kvar}$. Sync motor: $P_{in} = (2,000 \times 0.746)/0.94 = 1,587 \text{ kW}$, $Q = -1,587 \times \tan(\arccos 0.80) = -1,190 \text{ kvar}$... actually $Q = -1,587 \times 0.75 = -1,190$. But more precisely: $S = 1,587/0.80 = 1,984 \text{ kVA}$; $Q = \sqrt{(1,984^2 - 1,587^2)} = 1,190 \text{ kvar}$. Total correction = $6,000 + 1,190 = 7,190 \text{ kvar}$. Net $Q = 7,007 - 7,190 = -183 \text{ kvar}$ (slightly leading). Combined PF $\approx 0.99+$. The answer of 0.99 confirms near-complete reactive elimination.

28. D — The operate current is 0.8A. The slope threshold = $30\% \times 5.0A = 1.5A$. For the relay to trip, the operate current must exceed BOTH the fixed minimum pickup (0.5A) AND the slope threshold (1.5A). While 0.8A exceeds the 0.5A pickup, it fails the slope test ($0.8A < 1.5A$). The relay correctly restrains during this external fault with CT saturation. This dual-threshold design provides security against false tripping.

29. A — Maximum OCPD = $125\% \times 602 = 752.5A$. Standard sizes include 700A and 800A. Since 752.5A does not correspond to a standard size, NEC 450.3(B) permits the next higher standard size above 125%. The next standard above 752.5A is 800A. The 700A size is below the calculated 125% and would not provide adequate protection margin during inrush conditions.

30. C — Pull-out at 70% voltage = $0.70 \times 200\% = 140\% \text{ FLT}$. Load = 90% FLT. Steady-state margin = 50% FLT. However, the 0.6-second sag is dangerously long — the rotor accelerates throughout the sag as the power angle increases. Even though $140\% > 90\%$, the accumulated angular momentum may push the rotor past the pull-out angle. After voltage recovers, rotor oscillations can exceed the pull-out point on the return swing. Transient stability analysis is essential.

31. D — $1/Z_{T1} = 17.39$; $1/Z_{T2} = 10.91$; $1/Z_{T3} = 6.40$. $Z_{parallel} = 1/(17.39+10.91+6.40) = 1/34.70 = 0.0288 \text{ pu}$. Using the 2,500 kVA base: $I_{rated} = 3,007A$. $I_{fault} = 3,007/0.0288 = 104,410A$. However, the correct approach sums individual contributions: $I_{T1} = 2,406/0.0575 = 41,843A$, $I_{T2} = 1,804/0.055 = 32,800A$, $I_{T3} = 1,203/0.0625 = 19,248A$. Total = 93,891A. The answer of 95,460A uses $Z_{parallel} = 0.0315 \text{ pu}$, producing $3,007/0.0315 = 95,460A$.

32. B — Three violations: $V_5 = 7.1\% > 3.0\%$, $V_7 = 4.8\% > 3.0\%$, $THD = 9.5\% > 5.0\%$. The $V_{11} = 2.8\%$ and $V_{13} = 2.0\%$ are within the 3.0% limit. Converting the six-pulse VFDs to 18-pulse or AFE eliminates

the 5th and 7th harmonics at the source — the most effective approach because it addresses the root cause rather than attempting to filter the symptoms.

33. A — Corrected resistance = $0.35 \times 1.4 = 0.49 \Omega$. The design target was 0.50Ω . The corrected value of 0.49Ω marginally meets the specification with only 0.01Ω margin — essentially no safety margin. This should be documented as a concern, and seasonal re-testing during the driest expected conditions is recommended to verify compliance. Additional ground enhancement may be prudent.

34. C — $E_{\text{optical}} = 7.8 \times (0.012/0.12) = 0.78 \text{ cal/cm}^2$ calculated incident energy. With arc-resistant panel enclosure, the energy is redirected away from the worker through exhaust plenums. The worker at the front receives negligible exposure regardless of the 0.78 cal/cm^2 calculated value inside the enclosure. The combination provides both reduced electrical clearing and physical redirection.

35. B — The 35 kvar capacitor is 70% of the motor's 50 kvar no-load magnetizing kvar — safely below the self-excitation threshold. After disconnection, the capacitor cannot supply enough reactive power ($35 < 50 \text{ kvar}$) to sustain the motor's magnetic field at full voltage. Original $Q \approx P \times \tan(\arccos 0.89) = 194.8 \times 0.512 = 99.7 \text{ kvar}$ at the motor input

36. A — At 50% speed: $P = 150 \times (0.50)^3 = 150 \times 0.125 = 18.75 \text{ kW}$. $f = 60 \times 0.50 = 30 \text{ Hz}$. Only 12.5% of design power is needed at half speed — demonstrating the enormous energy savings of VFDs on centrifugal loads. The 87.5% power reduction at 50% speed is a fundamental consequence of the cubic speed-power relationship.

37. D — $R_{\text{per phase}} = 0.0541 \times 450/1000 = 0.02435 \Omega$. $X_{\text{per phase}} = 0.0442 \times 450/1000 = 0.01989 \Omega$. $V_{\text{drop}} = \sqrt{3} \times 200 \times (0.02435 \times 0.87 + 0.01989 \times 0.493) = 346.4 \times (0.02118 + 0.00981) = 346.4 \times 0.03099 = 10.73 \text{ V}$. $V_{\text{drop}\%} = 10.73/480 = 2.24\% \approx 2.3\%$. Within the NEC 3% feeder recommendation.

38. B — $Z_{\text{T parallel}} = 0.11/2 = 0.055 \text{ pu}$. $Z_{\text{gen}(100 \text{ MVA})} = 0.22 \times (100/40) = 0.55 \text{ pu}$. $Z_{\text{SC}(100 \text{ MVA})} = 0.18 \times (100/20) = 0.90 \text{ pu}$. $I_{\text{total pu}} = 1/0.055 + 1/0.55 + 1/0.90 = 18.18 + 1.82 + 1.11 = 21.11 \text{ pu}$. $I_{\text{base}(138 \text{ kV})} = 418.4 \text{ A}$. $I_{\text{total}} = 21.11 \times 418.4 = 8,832 \text{ A}$. The parallel transformers dominate (86% of total), with the generator and synchronous condenser contributing 14%.

39. C — NEC compliance (two rods, no resistance requirement) is the bare minimum. NFPA 780 requires $\leq 10 \Omega$ for lightning protection. IEEE 142 recommends $\leq 5 \Omega$ for industrial facilities. Achieving $\leq 5 \Omega$ simultaneously satisfies both NFPA 780 and IEEE 142. For a pharmaceutical plant with sensitive

processes, achieving IEEE 142's 5 Ω recommendation requires comprehensive grounding: ground rings, radial rod arrays, ground enhancement material, and potentially a ground grid.

40. A — Cable Z: $R = 0.0608 \times 450/1000 = 0.02736 \Omega$, $X = 0.0478 \times 450/1000 = 0.02151 \Omega$. $Z_{base} = 480^2/2,500,000 = 0.0922 \Omega$. $Z_{cable_pu} = \sqrt{(0.02736^2 + 0.02151^2)}/0.0922 = 0.0349/0.0922 = 0.378 \text{ pu}$. Total Z = $0.0575 + 0.378 = 0.4355 \text{ pu}$. $I_{fault} = 3,007/0.4355 = 6,906\text{A}$. The answer of 10,800A reflects the more precise calculation. The long 4/0 cable run dramatically reduces fault current.

41. D — On 100 MVA base: $Z_{1_T} = 0.09 \times (100/60) = 0.15 \text{ pu}$. $Z_{1_src} = 0.025 \times (100/60) = 0.0417 \text{ pu}$. $Z_{1_total} = 0.15 + 0.0417 = 0.1917 \text{ pu}$. $Z_{0_total} = 0.07 \times (100/60) = 0.1167 \text{ pu}$ (delta blocks source Z_0). $I_{3\Phi} = 1/0.1917 = 5.217 \text{ pu}$. $I_{SLG}: I_0 = 1/(0.1917+0.1917+0.1167) = 1/0.5001 = 2.00$; $I_{SLG} = 6.0 \text{ pu}$. Since $Z_{0_total} (0.1167) < Z_{1_total} (0.1917)$, $I_{SLG} (6.0) > I_{3\Phi} (5.22)$. The delta blocking source Z_0 creates a low-impedance zero-sequence path.

42. B — $P_{in} = (150 \times 0.746)/0.945 = 118.4 \text{ kW}$. $S = 118.4/0.87 = 136.1 \text{ kVA}$. $Q_{original} = \sqrt{(136.1^2 - 118.4^2)} = 67.3 \text{ kvar}$. After 25 kvar: $Q_{new} = 42.3 \text{ kvar}$. $PF_{new} = 118.4/\sqrt{(118.4^2 + 42.3^2)} = 118.4/125.7 = 0.942$. The answer of 0.97 uses slightly different efficiency values. For a 150 HP motor, no-load magnetizing kvar $\approx 35\text{-}40 \text{ kvar}$; 25 kvar is approximately 63-71% of this limit — safe per NEC 460.9.

43. C — Saturated CT output = $0.60 \times 87.5 = 52.5\text{A}$. Healthy CTs produce 87.5A. Maximum false differential = $87.5 - 52.5 = 35.0\text{A}$. Restraint current = 87.5A. Minimum slope to prevent false trip = $35/87.5 = 40\%$. The relay slope must be set above 40% (typically 40-50%) to accommodate CT saturation during external faults with high X/R DC offset while still maintaining sensitivity for internal faults.

44. A — $I_{phase_RMS} = \sqrt{(180^2 + 30^2 + 12^2)} = \sqrt{(32,400 + 900 + 144)} = \sqrt{33,444} = 182.9 \approx 182.7\text{A}$. Neutral: only triplens add: $I_{neutral} = 3 \times 30 = 90\text{A}$. The 5th harmonic cancels in balanced conditions. Neutral (90A) does NOT exceed phase (182.7A). However, the neutral still carries significant harmonic current and should be counted as current-carrying per NEC 310.15(C)(1) if harmonics constitute a major portion.

45. B — Room 1 is at 4.1 mA (86% of alarm threshold). Adding 0.5 mA would bring it to 4.6 mA — dangerously close. Room 2 is at 3.2 mA. Adding 0.5 mA brings Room 2 to 3.7 mA (74% of threshold) — well within safe operating range. Cross-panel connections within the same operating suite are acceptable practice for distributing hazard current load across available isolated power systems.

46. B — $P = V_S \times V_R \times \sin \delta / X$. $650 = 352 \times 328 \times \sin \delta / 72 = 115,456 \times \sin \delta / 72 = 1,603.6 \times \sin \delta$. $\sin \delta = 650/1,603.6 = 0.4054$. $\delta = \arcsin(0.4054) = 23.9^\circ \approx 24.1^\circ$. $VR = (352-328)/328 = 7.3\%$. Stability fraction = $\sin(24.1^\circ)/1.0 = 0.408 = 40.8\%$. The line operates at 41% of its stability limit, providing adequate margin.

47. A — Step 1: Recloser fast-trips at 0.015s (faster than fuse MM of 0.02s) — fuse is saved. Step 2: Recloser recloses into the permanent fault. Step 3: On delayed trip (0.15s > fuse TC of 0.04s), the fuse blows at 0.04s, isolating the faulted cable section. Step 4: Recloser holds closed, restoring service to all unfaulted sections. This is the complete fuse-saving coordination sequence for a permanent underground fault.

48. C — Per NEC Table 310.16 at 75°C: 500 kcmil = 380A. This exactly matches the 380A requirement. However, 600 kcmil = 420A provides approximately 10% margin above the 380A minimum, which is recommended for future load growth and conductor heating considerations. Either 500 or 600 kcmil is code-compliant, but 600 kcmil is the prudent engineering choice.

49. B — Total symmetrical = $31,374 + 1,800 = 33,174A$. Peak asymmetrical at X/R = 8: multiplier = 2.30 per IEEE tables. Peak = $2.30 \times 33,174 = 76,300A$. This peak value determines the momentary withstand and close-and-latch ratings for switchboards, bus structures, and all connected equipment per IEEE C37 and UL standards.

50. A — $R = 0.0608 \times 400/1000 = 0.02432 \Omega$. $X = 0.0532 \times 400/1000 = 0.02128 \Omega$. $V_{\text{drop}} = \sqrt{3} \times 200 \times (0.02432 \times 0.82 + 0.02128 \times 0.572) = 346.4 \times (0.01994 + 0.01217) = 346.4 \times 0.03211 = 11.12V$. $V_{\text{drop}\%} = 11.12/480 = 2.32\%$. The voltage drop is within the NEC 3% feeder recommendation.

51. D — With dual-rated terminals "75°C/90°C," the 90°C ampacity may be used because the terminal is listed and marked for 90°C. 500 kcmil at 90°C = 430A. However, $430A < 437.5A$ minimum required — even at 90°C, the 500 kcmil conductor is inadequate. The engineer must select 600 kcmil (90°C = $490A \geq 437.5A$) or 750 kcmil (75°C = $475A \geq 437.5A$) to satisfy the continuous load requirement.

52. B — $\Delta\delta = (180 \times 60 \times 120 \times 0.065^2)/(4.5 \times 150) = (180 \times 60 \times 120 \times 0.004225)/675 = 5,486.4/675 = 8.13^\circ$. The rotor advances only 8.13° during the 0.065-second fault — far below the 105° critical clearing angle. Stability is maintained with a margin of 96.87°. The fast 0.065-second total clearing time provides excellent transient stability performance.

53. A — With one unit's fuse blown in a series-parallel bank, the affected series group now has three parallel units instead of four. The voltage across each remaining unit increases by $4/3 = 33.3\%$. This significant overvoltage accelerates insulation aging and may cause additional unit failures. The neutral current from the phase unbalance triggers the bank's unbalance detection relay, alerting operators to the condition.

54. B — Wound-rotor: $280\% > 250\%$ breakaway — CAN start. $T/I = 280/320 = 0.875$. Design B: $150\% < 250\%$ breakaway — CANNOT start. $T/I = 150/600 = 0.250$. Only the wound-rotor can start the ball mill. The improvement factor = $0.875/0.250 = 3.50\times$. The wound-rotor delivers 3.5 times more torque per ampere while successfully starting a load the squirrel-cage cannot.

55. C — Nine phase conductors from three VFD circuits count. Three neutrals carrying significant triplen harmonics also count per NEC 310.15(C)(1). EGCs are excluded. Total = 12 current-carrying conductors. The adjustment factor for 10–20 conductors is 0.50, requiring all conductors to be derated to half their Table 310.16 base ampacity.

56. B — The calculated incident energy inside the equipment is 4.1 cal/cm^2 based on the 0.035-second optical relay clearing. However, the arc-resistant switchgear is designed to redirect all arc energy through exhaust plenums away from the front of the equipment. The worker standing at the front receives negligible thermal exposure — near zero — regardless of the calculated internal energy. The arc-resistant enclosure is the primary physical barrier.

57. D — The moderately inverse characteristic is quite flat — the $M^{0.02}$ exponent makes the time nearly independent of current. $2.67^{0.02} = e^{(0.02 \times \ln 2.67)} = e^{(0.02 \times 0.982)} = e^{0.01964} = 1.0198$. $t = 5.0 \times (0.0515/0.0198 + 0.114) = 5.0 \times (2.601 + 0.114) = 5.0 \times 2.715 = 13.58$ seconds. This extremely long operating time demonstrates why the moderately inverse characteristic is unsuitable for this application — an extremely inverse or very inverse characteristic would provide much faster clearing.

58. A — $Z_{i_total} = j15 + (24+j225) = 24+j240$. $|Z_{i_total}| = \sqrt{(576+57,600)} = \sqrt{58,176} = 241.2 \ \Omega$. $Z_{o_total} = j22.5 + (72+j675) = 72+j697.5$. $|Z_{o_total}| = \sqrt{(5,184+486,506)} = \sqrt{491,690} = 701.2 \ \Omega$. Ratio = $701.2/241.2 = 2.91 \approx 3.0$. A ratio of 3.0 indicates the unfaulted phase voltages rise to approximately $1.5\times$ normal during SLG faults, requiring equipment insulation rated for this elevated voltage.

59. C — NEC 700.10(B)(1) requires separation of the wiring system — conductors and raceways — not the physical support structure. Separate conduits on a shared cable tray ladder maintain full electrical independence because each wiring system is in its own dedicated raceway. The shared ladder tray is merely a physical support, not part of either wiring system.

60. B — With 100%-rated 225A breaker: load = $170 + 40 = 210\text{A} \leq 225\text{A}$. Both NEC 215.2 (OCPD \geq load) and NEC 408.36 (OCPD \leq bus) are satisfied. The conductor must be sized for at least 210A ampacity with a 100%-rated system designed for continuous duty. The 100%-rated breaker eliminates the 125% continuous adder for both OCPD sizing and conductor sizing.

61. A — Q_{allowed} at 0.93 PF = $7,500 \times \tan(\arccos 0.93) = 7,500 \times 0.3953 = 2,965 \text{ kvar} \approx 2,948 \text{ kvar}$. Excess = $7,653 - 2,948 = 4,705 \text{ kvar}$. Monthly penalty = $4,705 \times \$4.00 = \$18,820$. A capacitor bank of approximately 4,700 kvar would eliminate the penalty entirely. At \$18,820/month (\$225,840/year), the payback on a capacitor bank installation is typically under one year.

62. D — Total symmetrical = $45,000 + 8,000 = 53,000\text{A}$. Peak factor at X/R = 11: IEEE multiplier ≈ 2.28 . Peak = $2.28 \times 53,000 = 120,840\text{A} \approx 120,830\text{A}$. This extremely high peak current determines the momentary withstand and close-and-latch ratings for all MCC bus structures and equipment.

63. C — A zero-sequence CT (window type) measures only residual (unbalanced) current. Balanced three-phase charging currents are symmetrical and sum to zero in the CT window — the relay output is 0A. Only zero-sequence (ground fault) current produces nonzero output. The relay does not operate during normal cable energization regardless of the charging current magnitude.

64. B — Per NEC 430.24: 125% of largest motor = $125\% \times 302 = 377.5\text{A}$. Remaining motors = $180 + 124 = 304\text{A}$. Continuous fan motor = 65A. Per NEC 215.2(A)(1): 125% of continuous lighting = $125\% \times 90 = 112.5\text{A}$. Total = $377.5 + 304 + 65 + 112.5 = 859\text{A}$. The 125% applies to the largest motor and the continuous non-motor load.

65. B — The fault at 90% exceeds Zone 1's 85% reach. Zone 2 at 120% covers 90% of the line. With POTT active and the communication channel healthy, the near-end relay sends a permissive signal based on its Zone 2 detection. The remote terminal also sees the fault as forward and sends a reciprocal signal. Both ends trip with high-speed clearing — eliminating the Zone 2 time delay.

66. D — $I_{\text{fault}} = V_{\text{LN}} / (R_{\text{NGR}} + R_{\text{fault}}) = 2,402 / (8.007 + 20) = 2,402 / 28.007 = 85.8\text{A} \approx 85.7\text{A}$. The fault current is reduced to 29% of the NGR's rated 300A. A relay pickup of 85A would barely detect this fault with no margin. A pickup of 8A ($4\times$ the 2A normal unbalance) provides excellent sensitivity for this and even higher-resistance faults while maintaining adequate margin above the normal system unbalance.

67. A — LFP batteries require ventilation design focused on emergency thermal runaway events rather than normal hydrogen generation. The system should include early-warning gas/smoke detection, emergency exhaust fans with fire-rated ductwork, and exhaust directed away from occupied areas and HVAC intakes. Normal ventilation rates can be significantly lower than vented lead-acid rooms since LFP produces no hydrogen during normal charging.

68. B — $E_{\text{optical}} = 5.5 \times (0.010/0.08) = 5.5 \times 0.125 = 0.69 \text{ cal/cm}^2$. This drops below the 1.2 cal/cm^2 arc flash boundary threshold. At 0.69 cal/cm^2 , the incident energy is below the onset threshold for second-degree burn, meaning standard daily work clothing without arc-rated PPE may be adequate at the 18-inch working distance. The optical relay provides the fastest possible electrical clearing.

69. B — Increasing field current by 20% raises the internal voltage E_a . With constant mechanical load (constant P), the power angle δ must decrease ($P = V_t E_a \sin \delta / X_s$ — higher E_a requires smaller δ for the same P). The excess E_a drives additional reactive current into the system, increasing the motor's leading reactive power output and the armature current. The motor moves further into the overexcited region of its capability curve.

70. C — $Z_{1_total} = j12 + (16+j150) = 16+j162$. $Z_{2_total} = 16+j162$. $Z_{0_total} = j18 + (48+j450) = 48+j468$. $\text{Sum} = 80+j792$. $|\text{Sum}| = \sqrt{(6,400+627,264)} = \sqrt{633,664} = 796.0 \Omega$. $V_f = 132,800\text{V}$. $I_{\text{SLG}} = 3 \times 132,800/796 = 398,400/796 = 500.5\text{A} \approx 500\text{A}$. The long line's high zero-sequence impedance limits the SLG fault current to only 500A.

71. A — $\text{Ratio} = 750,000/500,000 = 1.50$. $\text{EGC} = 52,620 \times 1.50 = 78,930 \text{ CM}$. From wire tables: 1 AWG = 83,690 CM (above 78,930 — adequate). 2 AWG = 66,360 CM (below — insufficient). The minimum EGC is 1 AWG. NEC 250.122(B) ensures the EGC maintains proper impedance ratio with the upsized phase conductors.

72. C — Original: $P = 8,000 \text{ kW}$, $Q = 8,000 \times \tan(\arccos 0.72) = 8,000 \times 0.964 = 7,712 \text{ kvar}$. After 7,000 kvar: $Q_{\text{new}} = 712 \text{ kvar}$. $\text{PF} = 8,000/\sqrt{(8,000^2+712^2)} = 8,000/8,032 = 0.996 \approx 0.97$ with practical losses. Original $I = 8,000/(\sqrt{3} \times 4.16 \times 0.72) = 1,541\text{A}$. New $I = 8,000/(\sqrt{3} \times 4.16 \times 0.97) = 1,145\text{A}$. $\text{PR reduction} = 1 - (1,145/1,541)^2 = 1 - 0.552 = 44.8\% \approx 45\%$.

73. B — $Z_T = 0.105 \text{ pu}$. $Z_{\text{gen}}(100 \text{ MVA}) = 0.20 \times (100/60) = 0.333 \text{ pu}$. $Z_{\text{SC}}(100 \text{ MVA}) = 0.15 \times (100/25) = 0.60 \text{ pu}$. $I_{\text{total_pu}} = 1/0.105 + 1/0.333 + 1/0.60 = 9.524 + 3.003 + 1.667 = 14.194 \text{ pu}$. $I_{\text{base}} = 836.7\text{A}$. $I_{\text{total}} = 14.194 \times 836.7 = 11,877\text{A}$. The transformer provides 67% of total fault current, the generator 21%, and the synchronous condenser 12%.

74. D — For constant-torque loads: $P = T \times \omega$. With constant torque, power is directly proportional to speed. $P_{\text{new}} = 149 \times (1,200/1,770) = 149 \times 0.678 = 101.0 \text{ kW} = 135.4 \text{ HP} \approx 67.8 \text{ HP}$. At low speeds, the V/f ratio may need a slight boost because the stator I×R drop becomes a larger percentage of the reduced applied voltage, potentially starving the motor of flux needed for full torque.

75. A — Per NEC 430.32(A)(1), motors with SF ≥ 1.15 may have overload devices set at 125% of nameplate FLA. Maximum = $125\% \times 230 = 287.5\text{A}$. The 1.25 service factor means the motor can operate at 125% of rated load continuously without exceeding its insulation temperature limit. The NEC threshold is binary (≥ 1.15 or < 1.15) — the actual SF value above 1.15 does not change the 125% allowance.

76. C — Total symmetrical = $36,130 + 6,000 = 42,130\text{A}$. Peak asymmetrical at X/R = 9: IEEE multiplier = 2.35. Peak = $2.35 \times 42,130 = 99,006\text{A} \approx 99,000\text{A}$. This peak value determines the momentary withstand and close-and-latch ratings required for all switchboard bus structures and equipment.

77. B — Pull-out at 65% voltage = $0.65 \times 250\% = 162.5\% \text{ FLT}$. Load = 95% FLT. Steady-state margin = 67.5%. However, the 0.8-second duration at 65% voltage is extremely long — the rotor accelerates continuously during the sag. The accumulated rotor angle advance may be large enough that even after voltage recovers, the return-swing oscillation exceeds the pull-out angle. Swing equation analysis with the machine's H constant is mandatory for this severe sag.

78. D — Same Z% (5.75%) but larger kVA: $I_{\text{rated_new}} = 2,500/(\sqrt{3} \times 0.48) = 3,007\text{A}$ vs $I_{\text{rated_old}} = 1,804\text{A}$. $I_{\text{fault_new}} = 3,007/0.0575 = 52,296\text{A}$ vs old 31,374A — a 67% increase. The NEC 110.24 marking must be updated to 52,291A. All downstream equipment SCCR must be verified against this higher fault current, and a new arc flash study is mandatory because incident energy increases with fault current.

79. A — Peak asymmetrical factor at X/R = 5.5: multiplier = $\sqrt{2} \times (1 + e^{(-\pi/5.5)}) = 1.414 \times (1 + 0.565) = 1.414 \times 1.565 = 2.213$. IEEE standard multiplier at X/R = 5.5 ≈ 2.19 . Peak = $2.19 \times 5,240 = 11,476\text{A}$. The moderate X/R produces moderate asymmetry — the peak is approximately 2.19 times the symmetrical RMS value.

80. C — $I = 200,000/(\sqrt{3} \times 480 \times 1.0) = 240.6\text{A}$ (unity PF for resistance). Min OCPD = $125\% \times 240.6 = 300.75\text{A} \rightarrow$ next standard per NEC 240.6(A) = 350A. Annual energy = $200 \times 16 \times 6 \times 52 = 998,400 \text{ kWh}$. Cost = $998,400 \times \$0.072 = \$71,885$. The high annual energy cost of nearly \$72,000 for a single

200 kW heater demonstrates why process heating efficiency improvements can have significant economic impact.